

Τρίτη, 25 Ιανουάριος 2022		Προτεινόμενος ΗΕΠ Σκύρου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Εκτίμηση ζήτησης (MWh)		1,560	1,397	1,398	1,326	1,324	1,371	1,503	1,707	1,893	1,931	2,033	2,255	2,228	2,405	2,179	1,972	1,959	2,174	2,437	2,500	2,433	2,193	1,980	1,770	45,93	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	1,1																										Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη

