



ΗΣ ΛΗΜΝΟΥ				Απολογισμός Λειτουργίας									Πέμπτη, 30 Ιούνιος 2022		
Αποδιδόμενη Ισχύς (MW)				2,00	2,00	2,00	6,00	6,00	0,80	1,00	1,00	1,00			
Η Μ Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G9	Εντολή περιορισμού των αιολικών πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης αιολικής παραγωγής (MW)
Πέμπτη, 30 Ιούνιος 2022	30/06/22 0:00	7,08	6,40	0,68	0	0	0	1	1	0	0	0	0	0,90	1,18
	30/06/22 1:00	6,39	5,23	1,16	1	0	0	1	0	0	0	0	0	1,84	1,84
	30/06/22 2:00	6,13	5,09	1,04	1	0	0	1	0	0	0	0	0	1,70	1,70
	30/06/22 3:00	5,92	5,25	0,67	1	0	0	1	0	0	0	0	0	1,58	1,58
	30/06/22 4:00	5,86	5,19	0,67	1	0	0	1	0	0	0	0	0	1,51	1,52
	30/06/22 5:00	5,92	4,93	0,99	1	0	0	1	0	0	0	0	0	1,59	1,57
	30/06/22 6:00	6,12	5,54	0,58	1	0	0	1	0	0	0	0	0	1,75	1,75
	30/06/22 7:00	6,81	6,41	0,40	1	0	0	1	0	0	0	0	0	2,01	2,02
	30/06/22 8:00	7,59	7,06	0,53	1	0	1	1	0	0	0	0	0	2,14	2,15
	30/06/22 9:00	7,97	7,24	0,73	1	0	1	1	0	0	0	0	0	2,33	2,29
	30/06/22 10:00	8,14	7,38	0,75	1	0	1	1	0	0	0	0	0	2,41	2,42
	30/06/22 11:00	8,08	7,23	0,85	1	0	1	1	0	0	0	0	0	2,36	2,36
	30/06/22 12:00	8,44	6,78	1,67	1	0	1	1	0	0	0	0	0	2,33	2,33
	30/06/22 13:00	8,60	6,91	1,69	1	0	1	1	0	0	0	0	0	2,36	2,42
	30/06/22 14:00	8,21	6,16	2,05	1	0	1	1	0	0	0	0	0	2,27	2,22
	30/06/22 15:00	7,72	5,85	1,87	1	0	1	1	0	0	0	0	0	2,11	2,14
	30/06/22 16:00	7,53	5,80	1,73	1	0	0	1	0	0	0	0	0	2,06	2,06
	30/06/22 17:00	7,78	6,56	1,22	1	0	0	1	0	0	0	0	0	1,49	1,48
	30/06/22 18:00	8,62	7,94	0,68	0	0	0	1	1	0	0	0	0	2,09	2,09
	30/06/22 19:00	8,99	8,61	0,37	0	0	0	1	1	0	0	0	0	2,45	2,46
30/06/22 20:00	9,19	8,71	0,48	0	0	0	1	1	0	0	0	0	2,01	2,63	
30/06/22 21:00	9,58	8,81	0,77	0	0	0	1	1	0	0	0	0	2,80	2,78	
30/06/22 22:00	9,41	8,42	0,99	0	0	0	1	1	0	0	0	0	2,25	2,22	
30/06/22 23:00	8,29	7,21	1,08	0	0	0	1	1	0	0	0	0	1,40	1,37	

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης