

Δευτέρα, 8 Αύγουστος 2022		Απολογιστική λειτουργία ΗΣ Κύθνου																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		3,02	2,40	2,23	2,14	2,04	1,92	1,91	1,91	2,04	2,42	2,57	2,71	2,87	2,94	2,90	2,88	2,84	2,94	3,13	3,19	3,41	3,52	3,21	2,96	64,10
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1																Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MWM TBD603V12)	0,3																									Διαθέσιμη
G4 (MWM TBD603V12)	0,3																									Διαθέσιμη
G5 (MWM TBD603V12)	0,3																							1		Διαθέσιμη
G6 (MWM TBD603V12)	0,3																									Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
H/Z ENOIK.	1	1									1	1	2	2	2	2	2	2	2	2	2	2	2	1	1	Διαθέσιμη

Τρίτη, 9 Αύγουστος 2022		Απολογιστική λειτουργία ΗΣ Κύθνου																												
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)				
Ζήτηση (MWh)		3,00	2,51	2,31	2,19	2,05	1,95	1,90	1,96	2,13	2,45	2,62	2,68	2,72	2,75	2,77	2,81	2,79	2,85	2,99	3,18	3,44	3,59	3,21	2,99	63,83				
Μονάδα	Αποδιδόμενη Ισχύς (MW)																													
G1 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1																			1	1	1	1	Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1	1	1					1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MWM TBD603V12)	0,3																													Διαθέσιμη
G4 (MWM TBD603V12)	0,3																													Διαθέσιμη
G5 (MWM TBD603V12)	0,3																										1			Διαθέσιμη
G6 (MWM TBD603V12)	0,3																													Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
H/Z ENOIK.	1	1		1	1	1	1	1	1	1	1	1	2	2	2	2	2	2	2	2	2	2	1	1	1	1			Διαθέσιμη	

Τετάρτη, 10 Αύγουστος 2022		Απολογιστική λειτουργία ΗΣ Κύθου																												
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)				
Ζήτηση (MWh)		3,12	2,44	2,24	2,08	2,02	1,96	1,95	1,97	2,13	2,51	2,70	2,81	2,74	2,72	2,85	2,79	2,78	2,86	3,00	3,19	3,48	3,50	3,17	2,95	63,95				
Μονάδα	Αποδιδόμενη Ισχύς (MW)																													
G1 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1																1	1	1	1	Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MWM TBD603V12)	0,3																													Διαθέσιμη
G4 (MWM TBD603V12)	0,3																													Διαθέσιμη
G5 (MWM TBD603V12)	0,3																													Διαθέσιμη
G6 (MWM TBD603V12)	0,3																													Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
H/Z ENOIK.	1	1									1	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	1	Διαθέσιμη