

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα											Σάββατο 1/10/2022												
			Αποδιδόμενη Ισχύς (MW)						9	11	11	11	16	16	11	11,5	11,5	33	1,5	1,1	1,3	1,3	5,5	5,5	5,5	7,3
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	Πρόβλεψη Θερμικής Παραγωγής (MW)	Πρόβλεψη Αιολικής Παραγωγής (MW)	Πρόγραμμα ΥΒΣ Τήλου (MW)	ΑΣΠ Κω											ΑΣΠ Καλύμνου									
						G1	G2	G3	G4	G5	G6	A/Σ G7	A/Σ G32	A/Σ G33	A/Σ ενοικ.	MTU 9-11	x20 Η/Ζ	G1	G2	G3	G4	G5	G6			
Σάββατο	00:00	44,35	44,02	0,34	0,20			1	1	1	1									1	1				1	
	01:00	41,83	41,15	0,68	0,20				1	1	1									1	1				1	
	02:00	40,18	39,59	0,59	0,20				1	1	1									1	1				1	
	03:00	39,35	38,95	0,40	0,20				1	1	1									1	1				1	
	04:00	38,89	38,39	0,50	0,20				1	1	1									1	1				1	
	05:00	40,57	40,20	0,37	0,20				1	1	1									1	1				1	
	06:00	44,14	43,85	0,29	0,20			1		1	1	1								1	1				1	
	07:00	49,21	48,95	0,26	0,20			1		1	1	1								1	1				1	
	08:00	53,34	52,96	0,38	0,20			1	1	1	1	1								1	1				1	
	09:00	55,48	54,55	0,92	0,20			1	1	1	1	1								1	1				1	
	10:00	55,10	53,81	1,29	0,20			1	1	1	1	1								1	1				1	
	11:00	54,15	53,35	0,80	0,20			1	1	1	1	1								1	1				1	
	12:00	54,58	52,77	1,81	0,20			1	1	1	1	1								1	1				1	
	13:00	55,01	50,13	4,89	0,20			1	1	1	1	1								1	1				1	
	14:00	52,72	46,69	6,04	0,20			1	1	1	1	1								1	1				1	
	15:00	49,94	43,68	6,26	0,20			1	1	1	1	1								1	1				1	
	16:00	51,24	46,42	4,82	0,20			1	1	1	1	1								1	1				1	
	17:00	55,39	51,23	4,16	0,20		1	1	1	1	1	1								1	1				1	
	18:00	60,95	57,22	3,73	0,20		1	1	1	1	1	1								1	1				1	
	19:00	66,89	63,93	2,96	0,20		1	1	1	1	1	1								1	1				1	
	20:00	65,43	62,42	3,01	0,20		1	1	1	1	1	1								1	1				1	
	21:00	60,16	58,99	1,17	0,20		1	1	1	1	1	1								1	1				1	
	22:00	53,24	52,77	0,47	0,20			1	1	1	1	1								1	1				1	
23:00	48,15	47,96	0,19	0,20			1	1	1	1	1								1	1				1		

Παρατηρήσεις

1 μονάδα MTU και 2 Mitsubishi του ΑΣΠ Κω είναι μη διαθέσιμα.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.