

Τετάρτη, 12 Οκτώβριος 2022		Απολογισμός λειτουργίας ΗΣ Σκύρου																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,162	1,165	1,104	1,064	1,050	1,065	1,185	1,259	1,317	1,343	1,286	1,200	1,251	1,284	1,199	1,064	1,101	1,235	1,338	1,633	1,673	1,524	1,331	1,183	30,02
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1,1																				1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1									1	1	1	1	1	1	1	1	1	1	1						Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	0,7																									Διαθέσιμη