

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ			Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα											Τετάρτη 1/3/2023												
			Αποδιδόμενη Ισχύς (MW)						9	11	11	11	16	16	11	11,5	11,5	33	1,5	1,1	1,8	1,8	5,88	5,88	5,88	8,25
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	Πρόβλεψη Θερμικής Παραγωγής (MW)	Πρόβλεψη Αιολικής Παραγωγής (MW)	Πρόγραμμα ΥΒΣ Τήλου (MW)	ΑΣΠ Κω											ΑΣΠ Καλύμνου									
						G1	G2	G3	G4	G5	G6	A/Σ G7	A/Σ G32	A/Σ G33	A/Σ ενοικ.	MTU 9-11	x20 H/Z	G1	G2	G3	G4	G5	G6			
Τετάρτη	00:00	25,05	17,83	7,23	0,00				1		1														1	
	01:00	22,98	17,83	5,15	0,00				1		1														1	
	02:00	22,88	17,83	5,05	0,00				1		1														1	
	03:00	22,16	17,83	4,33	0,00				1		1														1	
	04:00	21,69	17,83	3,86	0,00				1		1														1	
	05:00	22,35	17,83	4,52	0,00				1		1														1	
	06:00	24,73	18,35	6,38	0,00				1		1														1	
	07:00	27,85	23,13	4,72	0,00				1		1														1	
	08:00	26,92	22,86	4,06	0,00				1		1														1	
	09:00	26,05	22,78	3,27	0,00				1		1														1	
	10:00	25,91	22,80	3,11	0,00				1		1														1	
	11:00	26,82	22,80	4,03	0,20				1		1														1	
	12:00	27,33	23,13	4,20	0,20				1		1														1	
	13:00	27,39	24,50	2,89	0,20				1		1														1	
	14:00	26,72	25,43	1,29	0,20				1		1														1	
	15:00	27,54	26,74	0,80	0,00				1		1														1	
	16:00	29,15	28,56	0,60	0,00				1	1	1														1	
	17:00	31,83	30,96	0,87	0,00				1	1	1														1	
	18:00	36,78	35,61	1,17	0,00				1	1	1														1	
	19:00	39,08	37,52	1,56	0,00				1	1	1														1	
	20:00	38,77	36,84	1,93	0,00				1	1	1														1	
	21:00	36,51	34,87	1,63	0,00				1	1	1														1	
	22:00	32,93	31,09	1,84	0,00				1	1	1														1	
23:00	28,41	26,45	1,95	0,00				1		1														1		

Παρατηρήσεις

4 HZ Mitsubishi του ΑΣΠ Κω είναι μη διαθέσιμα λόγω βλάβης και συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.