





ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 8 Ιούνιος 2023							
		Αποδιδόμενη Ισχύς (MW)	1,100	0,550	0,550	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ τ ε π	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Πέμπτη, 8 Ιούνιος 2023	00:00	1,493	1,493	1			1	
01:00	1,389	1,389	1				1					
02:00	1,391	1,391	1				1					
03:00	1,388	1,388					1	1				
04:00	1,360	1,360					1	1				
05:00	1,362	1,362					1	1				
06:00	1,339	1,339					1	1				
07:00	1,381	1,381					1	1				
08:00	1,626	1,626					1	1				
09:00	1,679	1,679	1				1					
10:00	1,730	1,730	1				1					
11:00	1,734	1,734	1				1					
12:00	1,928	1,928	1				1			1		
13:00	1,971	1,971	1				1			1		
14:00	1,940	1,940	1				1			1		
15:00	1,799	1,799	1				1			1		
16:00	1,598	1,598	1				1					
17:00	1,711	1,711	1				1					
18:00	1,808	1,808	1				1					
19:00	1,912	1,912	1				1			1		
20:00	1,958	1,958	1				1			1		
21:00	1,935	1,935	1				1			1		
22:00	1,795	1,795	1				1			1		
23:00	1,636	1,636	1				1					

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης



ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 9 Ιούνιος 2023							
		Αποδιδόμενη Ισχύς (MW)	1,100	0,550	0,550	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Π Ε Ρ Α Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Παρασκευή, 9 Ιούνιος 2023	00:00	1,491	1,491	1			1	
01:00	1,395	1,395	1				1					
02:00	1,367	1,367	1				1					
03:00	1,357	1,357	1				1					
04:00	1,349	1,349	1				1					
05:00	1,324	1,324	1				1					
06:00	1,296	1,296	1				1					
07:00	1,581	1,581	1				1					
08:00	1,723	1,723	1				1					
09:00	1,706	1,706	1				1					
10:00	1,791	1,791	1				1					
11:00	1,854	1,854	1				1					
12:00	1,908	1,908	1				1			1		
13:00	1,879	1,879	1				1			1		
14:00	1,860	1,860	1				1			1		
15:00	1,787	1,787	1				1					
16:00	1,722	1,722	1				1					
17:00	1,670	1,670	1				1					
18:00	1,678	1,678	1				1					
19:00	1,799	1,799	1				1					
20:00	1,980	1,980	1				1			1		
21:00	1,949	1,949	1				1			1		
22:00	1,745	1,745	1				1			1		
23:00	1,638	1,638	1				1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης



ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 10 Ιούνιος 2023							
		Αποδιδόμενη Ισχύς (MW)		1,100	0,550	0,550	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Σάββατο, 10 Ιούνιος 2023	00:00	1,514	1,514	1			1	
01:00	1,413	1,413	1				1					
02:00	1,406	1,406	1				1					
03:00	1,400	1,400	1				1					
04:00	1,380	1,380	1				1					
05:00	1,380	1,380	1				1					
06:00	1,364	1,364	1				1					
07:00	1,523	1,523	1				1					
08:00	1,702	1,702	1				1					
09:00	1,769	1,769	1				1					
10:00	1,859	1,859	1				1					
11:00	1,881	1,881	1				1			1		
12:00	1,946	1,946	1				1			1		
13:00	1,938	1,938	1				1			1		
14:00	1,944	1,944	1				1			1		
15:00	1,861	1,861	1				1			1		
16:00	1,755	1,755	1				1					
17:00	1,813	1,813	1				1					
18:00	1,934	1,934	1				1			1		
19:00	1,994	1,994	1				1			1		
20:00	1,945	1,945	1				1			1		
21:00	2,000	2,000	1				1			1		
22:00	1,828	1,828	1				1			1		
23:00	1,660	1,660	1				1					

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 11 Ιούνιος 2023							
		Αποδιδόμενη Ισχύς (MW)	1,100	0,550	0,550	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ τ ε π η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Κυριακή, 11 Ιούνιος 2023	00:00	1,560	1,560	1			1	
01:00	1,462	1,462	1				1					
02:00	1,402	1,402	1				1					
03:00	1,380	1,380	1				1					
04:00	1,407	1,407	1				1					
05:00	1,400	1,400	1					1				
06:00	1,351	1,351	1					1				
07:00	1,560	1,560	1					1				
08:00	1,693	1,693	1					1				
09:00	1,719	1,719	1				1					
10:00	1,825	1,825	1				1					
11:00	1,847	1,847	1				1					
12:00	1,945	1,945	1				1			1		
13:00	1,960	1,960	1				1			1		
14:00	1,935	1,935	1				1			1		
15:00	1,791	1,791	1				1			1		
16:00	1,671	1,671	1				1					
17:00	1,749	1,749	1				1					
18:00	1,813	1,813	1				1					
19:00	1,885	1,885	1				1			1		
20:00	1,924	1,924	1				1			1		
21:00	1,951	1,951	1				1			1		
22:00	1,843	1,843	1				1			1		
23:00	1,719	1,719	1				1					

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης



ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 12 Ιούνιος 2023							
		Αποδιδόμενη Ισχύς (MW)	1,100	0,550	0,550	1,100	1,100	1,100	1,100	1,100	1,100	1,100
α ρ τ ε π η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Δευτέρα, 12 Ιούνιος 2023	00:00	1,551	1,551	1			1	
01:00	1,454	1,454	1				1					
02:00	1,470	1,470	1				1					
03:00	1,417	1,417	1				1					
04:00	1,408	1,408	1				1					
05:00	1,363	1,363	1				1					
06:00	1,389	1,389	1				1					
07:00	1,619	1,619	1				1					
08:00	1,774	1,774	1				1					
09:00	1,851	1,851	1				1			1		
10:00	1,881	1,881	1				1	1				
11:00	1,886	1,886	1				1	1				
12:00	1,965	1,965	1				1	1				
13:00	1,986	1,986	1				1	1				
14:00	1,925	1,925	1				1	1				
15:00	1,805	1,805	1				1	1				
16:00	1,725	1,725	1				1					
17:00	1,785	1,785	1				1					
18:00	1,865	1,865	1				1	1				
19:00	1,943	1,943	1				1	1				
20:00	2,010	2,010	1				1	1				
21:00	2,053	2,053	1				1	1				
22:00	1,915	1,915	1				1	1				
23:00	1,774	1,774	1				1					

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 13 Ιούνιος 2023							
		Αποδιδόμενη Ισχύς (MW)	1,100	0,550	0,550	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Τρίτη, 13 Ιούνιος 2023	00:00	1,563	1,563	1			1	
01:00	1,453	1,453	1				1					
02:00	1,406	1,406	1				1					
03:00	1,405	1,405	1				1					
04:00	1,407	1,407	1				1					
05:00	1,401	1,401	1				1					
06:00	1,381	1,381	1				1					
07:00	1,626	1,626	1				1					
08:00	1,715	1,715	1				1					
09:00	1,832	1,832	1				1	1				
10:00	1,871	1,871	1				1	1				
11:00	1,899	1,899	1				1	1				
12:00	2,012	2,012	1				1	1				
13:00	2,014	2,014	1				1	1				
14:00	1,932	1,932	1				1	1				
15:00	1,799	1,799	1				1	1				
16:00	1,723	1,723	1				1	1				
17:00	1,775	1,775	1				1					
18:00	1,958	1,958	1				1	1				
19:00	2,031	2,031	1				1	1				
20:00	2,044	2,044	1				1	1				
21:00	2,028	2,028	1				1	1				
22:00	1,916	1,916	1				1	1				
23:00	1,721	1,721	1				1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 14 Ιούνιος 2023							
		Αποδιδόμενη Ισχύς (MW)		1,100	0,550	0,550	1,100	1,100	1,100	1,100	1,100	1,100
α ρ τ ε π η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Τετάρτη, 14 Ιούνιος 2023	00:00	1,530	1,530	1			1	
01:00	1,439	1,439	1				1					
02:00	1,366	1,366	1				1					
03:00	1,404	1,404	1				1					
04:00	1,417	1,417	1				1					
05:00	1,388	1,388	1				1					
06:00	1,382	1,382	1				1					
07:00	1,621	1,621	1				1					
08:00	1,705	1,705	1				1					
09:00	1,870	1,870	1				1	1				
10:00	1,945	1,945	1				1	1				
11:00	1,956	1,956	1				1	1				
12:00	1,975	1,975	1				1	1				
13:00	1,943	1,943	1				1	1				
14:00	1,929	1,929	1				1	1				
15:00	1,852	1,852	1				1	1				
16:00	1,747	1,747	1				1	1				
17:00	1,792	1,792	1				1					
18:00	1,925	1,925	1				1	1				
19:00	1,986	1,986	1				1	1				
20:00	2,041	2,041	1				1	1				
21:00	1,982	1,982	1				1	1				
22:00	1,722	1,722	1				1	1				
23:00	1,701	1,701	1				1					

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης