







ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Πέμπτη, 6 Ιούλιος 2023							
		Αποδιδόμενη Ισχύς (MW)		1,100	0,550	0,550	1,100	1,100	0,450	0,600	1,100	1,100
α ρ τ ε π	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Πέμπτη, 6 Ιούλιος 2023	00:00	2,224	2,224	1			1	1
01:00	2,070	2,070	1				1	1				
02:00	1,990	1,990	1				1	1				
03:00	1,922	1,922	1				1	1				
04:00	1,885	1,885	1				1	1				
05:00	1,838	1,838	1				1	1				
06:00	1,727	1,727	1				1	1				
07:00	1,894	1,894	1				1	1				
08:00	2,156	2,156	1				1	1				
09:00	2,358	2,358	1				1	1			1	
10:00	2,403	2,403					1	1			1	
11:00	2,589	2,589					1	1			1	
12:00	2,625	2,625					1	1			1	
13:00	2,756	2,756					1	1		1	1	
14:00	2,802	2,802					1	1		1	1	
15:00	2,675	2,675					1	1		1	1	
16:00	2,652	2,652					1	1		1	1	
17:00	2,627	2,627					1	1			1	
18:00	2,696	2,696					1	1			1	
19:00	2,832	2,832					1	1		1	1	
20:00	2,731	2,731					1	1		1	1	
21:00	2,711	2,711	1				1	1			1	
22:00	2,594	2,594	1				1	1				
23:00	2,439	2,439	1				1	1				

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης



ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Παρασκευή, 7 Ιούλιος 2023							
		Αποδιδόμενη Ισχύς (MW)	1,100	0,550	0,550	1,100	1,100	0,450	0,600	1,100	1,100	
Π Ε Ρ Ε Τ Η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Παρασκευή, 7 Ιούλιος 2023	00:00	2,263	2,263	1			1	1
01:00	2,099	2,099	1				1	1				
02:00	2,034	2,034	1				1	1				
03:00	1,961	1,961	1				1	1				
04:00	1,899	1,899	1				1	1				
05:00	1,838	1,838	1				1	1				
06:00	1,749	1,749	1				1	1				
07:00	1,918	1,918	1				1	1				
08:00	2,137	2,137	1				1	1				
09:00	2,281	2,281	1				1	1				
10:00	2,406	2,406	1				1	1				
11:00	2,602	2,602	1				1	1		1		
12:00	2,669	2,669	1				1	1		1		
13:00	2,703	2,703	1				1	1		1		
14:00	2,680	2,680	1				1	1		1		
15:00	2,632	2,632	1				1	1		1		
16:00	2,632	2,632	1				1	1				
17:00	2,641	2,641	1				1	1				
18:00	2,719	2,719	1				1	1		1		
19:00	2,765	2,765	1				1	1		1		
20:00	2,717	2,717	1				1	1		1		
21:00	2,632	2,632	1				1	1		1		
22:00	2,696	2,696	1				1	1		1		
23:00	2,644	2,644	1				1	1		1		

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Σάββατο, 8 Ιούλιος 2023							
		Αποδιδόμενη Ισχύς (MW)	1,100	0,550	0,550	1,100	1,100	0,450	0,600	1,100	1,100	
α ρ τ ε π η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Σάββατο, 8 Ιούλιος 2023	00:00	2,370	2,370				1	1
01:00	2,220	2,220					1	1			1	
02:00	2,150	2,150					1	1			1	
03:00	2,063	2,063					1	1			1	
04:00	2,045	2,045					1	1			1	
05:00	2,002	2,002					1	1		1		
06:00	1,870	1,870					1	1		1		
07:00	2,071	2,071					1	1		1		
08:00	2,201	2,201					1	1			1	
09:00	2,372	2,372					1	1			1	
10:00	2,473	2,473					1	1			1	
11:00	2,482	2,482					1	1			1	
12:00	2,645	2,645					1	1		1	1	
13:00	2,852	2,852					1	1		1	1	
14:00	2,819	2,819					1	1		1	1	
15:00	2,764	2,764					1	1		1	1	
16:00	2,566	2,566					1	1		1	1	
17:00	2,669	2,669					1	1			1	
18:00	2,684	2,684					1	1			1	
19:00	2,665	2,665					1	1			1	
20:00	2,706	2,706					1	1		1	1	
21:00	2,816	2,816					1	1		1	1	
22:00	2,764	2,764					1	1		1	1	
23:00	2,611	2,611					1	1		1	1	

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Κυριακή, 9 Ιούλιος 2023							
		Αποδιδόμενη Ισχύς (MW)	1,100	0,550	0,550	1,100	1,100	0,450	0,600	1,100	1,100	
Π Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Κυριακή, 9 Ιούλιος 2023	00:00	2,468	2,468				1	1
01:00	2,288	2,288					1	1			1	
02:00	2,210	2,210					1	1			1	
03:00	2,053	2,053					1	1			1	
04:00	1,922	1,922					1	1			1	
05:00	2,003	2,003					1	1			1	
06:00	1,922	1,922					1	1			1	
07:00	2,048	2,048					1	1			1	
08:00	2,152	2,152					1	1			1	
09:00	2,232	2,232	1				1	1			1	
10:00	2,343	2,343	1				1	1			1	
11:00	2,452	2,452	1				1	1			1	
12:00	2,476	2,476	1				1	1				
13:00	2,618	2,618	1				1	1				
14:00	2,573	2,573	1				1	1				
15:00	2,512	2,512	1				1	1				
16:00	2,451	2,451	1				1	1				
17:00	2,495	2,495	1				1	1				
18:00	2,556	2,556	1				1	1				
19:00	2,562	2,562	1				1	1				
20:00	2,596	2,596	1				1	1				
21:00	2,645	2,645	1				1	1				
22:00	2,569	2,569	1				1	1				
23:00	2,426	2,426	1				1	1				

 Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Δευτέρα, 10 Ιούλιος 2023							
		Αποδιδόμενη Ισχύς (MW)		1,100	0,550	0,550	1,100	1,100	0,450	0,600	1,100	1,100
α ρ τ ε π	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Δευτέρα, 10 Ιούλιος 2023	00:00	2,262	2,262	1			1	1
01:00	2,153	2,153	1				1	1				
02:00	2,094	2,094	1				1	1				
03:00	2,008	2,008	1				1	1				
04:00	1,956	1,956	1				1	1				
05:00	1,920	1,920	1				1	1				
06:00	1,841	1,841	1				1	1				
07:00	2,083	2,083	1				1	1				
08:00	2,303	2,303	1				1	1				
09:00	2,126	2,126	1				1	1				
10:00	2,169	2,169	1				1	1				
11:00	2,512	2,512	1				1	1				
12:00	2,584	2,584	1				1	1				
13:00	2,658	2,658	1				1	1				
14:00	2,681	2,681	1				1	1				
15:00	2,558	2,558	1				1	1				
16:00	2,530	2,530	1				1	1				
17:00	2,605	2,605	1				1	1				
18:00	2,628	2,628	1				1	1				
19:00	2,764	2,764	1				1	1		1		
20:00	2,806	2,806	1				1	1		1		
21:00	2,864	2,864	1				1	1		1		
22:00	2,842	2,842	1				1	1		1		
23:00	2,717	2,717	1				1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τρίτη, 11 Ιούλιος 2023							
		Αποδιδόμενη Ισχύς (MW)	1,100	0,550	0,550	1,100	1,100	0,450	0,600	1,100	1,100	
Α ρ χ η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Τρίτη, 11 Ιούλιος 2023	00:00	2,509	2,509	1			1	1
01:00	2,343	2,343	1				1	1				
02:00	2,222	2,222	1				1	1				
03:00	2,136	2,136	1				1	1				
04:00	2,087	2,087	1				1	1				
05:00	2,041	2,041	1				1	1				
06:00	1,951	1,951	1				1	1				
07:00	2,144	2,144	1				1	1				
08:00	2,186	2,186	1				1	1				
09:00	2,299	2,299	1				1	1				
10:00	2,314	2,314	1				1	1				
11:00	2,192	2,192	1				1	1				
12:00	2,573	2,573	1				1	1		1		
13:00	2,531	2,531	1				1	1		1		
14:00	2,768	2,768	1				1	1		1		
15:00	2,598	2,598	1				1	1		1		
16:00	2,634	2,634	1				1	1				
17:00	2,556	2,556	1				1	1				
18:00	2,403	2,403	1				1	1				
19:00	2,808	2,808	1				1	1		1		
20:00	2,742	2,742	1				1	1		1		
21:00	2,899	2,899	1				1	1		1		
22:00	2,575	2,575	1				1	1		1		
23:00	2,746	2,746	1				1	1		1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΥΜΗΣ		Απολογισμός Λειτουργίας			Τετάρτη, 12 Ιούλιος 2023							
		Αποδιδόμενη Ισχύς (MW)	1,100	0,550	0,550	1,100	1,100	0,450	0,600	1,100	1,100	
α ρ τ ε π η	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	G1	G2	G3	G4	G5	G6	G7	G8	G24
				Τετάρτη, 12 Ιούλιος 2023	00:00	2,596	2,596	1			1	1
01:00	2,423	2,423	1				1	1				
02:00	2,273	2,273	1				1	1				
03:00	2,207	2,207	1				1	1				
04:00	2,148	2,148	1				1	1				
05:00	2,097	2,097	1				1	1		1		
06:00	1,994	1,994	1					1		1		
07:00	2,205	2,205	1					1			1	
08:00	2,303	2,303	1					1			1	
09:00	2,295	2,295	1				1	1			1	
10:00	2,388	2,388	1				1	1				
11:00	2,486	2,486	1				1	1				
12:00	2,591	2,591	1				1	1				
13:00	2,842	2,842	1				1	1		1		
14:00	2,892	2,892	1				1	1		1		
15:00	2,873	2,873	1				1	1		1		
16:00	2,691	2,691	1				1	1		1		
17:00	2,807	2,807	1				1	1		1		
18:00	2,940	2,940	1				1	1		1		
19:00	3,001	3,001	1				1	1		1		
20:00	3,037	3,037	1				1	1			1	
21:00	3,106	3,106	1				1	1			1	
22:00	3,032	3,032	1				1	1			1	
23:00	2,878	2,878	1				1	1			1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης