

Παρασκευή, 21 Ιούλιος 2023		Απολογισμός λειτουργίας ΗΣ Σκύρου																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		3,067	2,859	2,650	2,478	2,368	2,371	2,298	2,451	2,804	2,955	3,119	3,085	3,159	3,336	3,402	3,337	3,266	3,298	3,432	3,547	3,555	3,618	3,400	3,220	73,07
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1						Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G7 (MITSUBISHI S16R-PTA)	1																			1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1																				1	1	1	1	1	Διαθέσιμη

Κυριακή, 23 Ιούλιος 2023		Απολογισμός λειτουργίας ΗΣ Σκύρου																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		3,513	3,408	3,262	3,206	3,068	2,981	2,869	3,021	3,270	3,486	3,706	3,736	3,915	4,026	3,956	4,003	3,909	3,810	3,807	3,806	3,919	4,076	3,868	3,681	86,30
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1				Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1,1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G5 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (MITSUBISHI S16R-PTA)	-																								Συντήρηση	
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1				1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G8 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1														1	1	1	Διαθέσιμη

Δευτέρα, 24 Ιούλιος 2023		Απολογισμός λειτουργίας ΗΣ Σκύρου																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		3,581	3,403	3,220	3,040	2,898	2,793	2,746	2,777	2,956	3,117	3,219	3,165	3,281	3,419	3,432	3,559	3,559	3,559	3,559	3,559	3,559	3,584	3,559	3,559	79,10
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (MITSUBISHI S16R-PTA)	1,1														1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1			Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1		1	1	1	1	1	1	1											1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1	1															1	1	1	1	1			1	1	Διαθέσιμη

Τρίτη, 25 Ιούλιος 2023		Απολογισμός λειτουργίας ΗΣ Σκύρου																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		3,559	3,559	3,559	3,559	3,559	3,559	3,559	3,559	3,559	3,559	3,317	3,131	3,306	3,416	3,590	3,540	3,414	3,412	3,461	3,524	3,548	3,673	3,512	3,389	83,82	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G5 (MITSUBISHI S16R-PTA)	1,1														1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G6 (MITSUBISHI S16R-PTA)	-																									Συντήρηση	
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1											Διαθέσιμη	
G8 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1												1	1	1	Διαθέσιμη

Τετάρτη, 26 Ιούλιος 2023		Απολογισμός λειτουργίας ΗΣ Σκύρου																									
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		3,339	3,119	3,004	2,855	2,712	2,630	2,543	2,740	3,000	3,362	3,604	3,720	3,940	4,205	4,457	4,476	4,500	4,382	4,397	4,332	4,411	4,443	4,243	4,198	88,61	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (MITSUBISHI S16R-PTA)	1,1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1,1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G8 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1						1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη