



Παρασκευή, 28 Ιούλιος 2023		Απολογιστική λειτουργία ΗΣ Κύθου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,818	2,613	2,498	2,395	2,299	2,244	2,167	2,233	2,304	2,412	2,440	2,560	2,587	2,621	2,664	2,666	2,751	2,792	2,843	2,873	2,910	3,112	2,921	2,784	62,51	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1	1	1								1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1			1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MWM TBD603V12)	0,3																										Διαθέσιμη
G4 (MWM TBD603V12)	0,3																										Διαθέσιμη
G5 (MWM TBD603V12)	0,3																										Διαθέσιμη
G6 (MWM TBD603V12)	0,3																										Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
2 ΦΟΡΗΤΑ Η/Ζ	1	2	2	2								2	1	1	1	1	1	1	1	2	2	2	2	2	2	1	Διαθέσιμη

Σάββατο, 29 Ιούλιος 2023		Απολογιστική λειτουργία ΗΣ Κύθου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,603	2,384	2,277	2,175	2,113	2,077	2,065	2,130	2,248	2,382	2,426	2,578	2,604	2,605	2,649	2,602	2,613	2,736	2,844	2,965	3,036	3,178	3,029	2,754	61,07	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MWM TBD603V12)	0,3																										Διαθέσιμη
G4 (MWM TBD603V12)	0,3																										Διαθέσιμη
G5 (MWM TBD603V12)	0,3																										Διαθέσιμη
G6 (MWM TBD603V12)	0,3																										Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
2 ΦΟΡΗΤΑ Η/Ζ	1	1	1										0	1	1	1	1	1	1	1	1	1	1	2	2	2	Διαθέσιμη

Κυριακή, 30 Ιούλιος 2023		Απολογιστική λειτουργία ΗΣ Κύθου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,625	2,487	2,361	2,212	2,107	2,060	2,065	2,142	2,299	2,459	2,524	2,669	2,650	2,707	2,733	2,665	2,640	2,732	2,892	2,985	2,956	3,074	2,971	2,790	61,81	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MWM TBD603V12)	0,3																										Διαθέσιμη
G4 (MWM TBD603V12)	0,3																										Διαθέσιμη
G5 (MWM TBD603V12)	0,3																										Διαθέσιμη
G6 (MWM TBD603V12)	0,3																										Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1	1	1	1																1	1	1	1	1	1	1	Διαθέσιμη
2 ΦΟΡΗΤΑ Η/Ζ	1	1	1	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	1	Διαθέσιμη

Δευτέρα, 31 Ιούλιος 2023		Απολογιστική λειτουργία ΗΣ Κύθου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,639	2,443	2,309	2,154	2,068	2,040	2,011	2,127	2,253	2,441	2,653	2,720	2,696	2,693	2,798	2,847	2,854	2,896	2,902	2,997	3,090	3,109	2,877	2,705	62,32	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MWM TBD603V12)	0,3																										Διαθέσιμη
G4 (MWM TBD603V12)	0,3																										Διαθέσιμη
G5 (MWM TBD603V12)	0,3																										Διαθέσιμη
G6 (MWM TBD603V12)	0,3																										Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
2 ΦΟΡΗΤΑ Η/Ζ	1	1	1	1								1	1	1	1	1	2	2	2	2	2	2	2	2	1	Διαθέσιμη	

Τρίτη, 1 Αύγουστος 2023		Απολογιστική λειτουργία ΗΣ Κύθνου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,522	2,350	2,273	2,145	2,057	2,014	2,018	2,064	2,189	2,357	2,508	2,620	2,660	2,684	2,743	2,743	2,769	2,775	2,929	3,018	3,057	3,127	2,966	2,823	61,41	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MWM TBD603V12)	0,3																										Βλάβη
G4 (MWM TBD603V12)	0,3																										Διαθέσιμη
G5 (MWM TBD603V12)	0,3																										Διαθέσιμη
G6 (MWM TBD603V12)	0,3																										Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
2 ΦΟΡΗΤΑ Η/Ζ	1	1	1												1	1	1	1	1	1	2	2	2	2	2	Διαθέσιμη	

Τετάρτη, 2 Αύγουστος 2023		Απολογιστική λειτουργία ΗΣ Κύθου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		2,617	2,386	2,287	2,161	2,069	2,032	2,023	2,043	2,252	2,399	2,533	2,673	2,708	2,758	2,788	2,857	2,941	2,959	3,048	3,104	3,199	3,287	3,110	2,981	63,22	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G3 (MWM TBD603V12)	0,3																										Βλάβη
G4 (MWM TBD603V12)	0,3																										Διαθέσιμη
G5 (MWM TBD603V12)	0,3																										Διαθέσιμη
G6 (MWM TBD603V12)	0,3																										Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
2 ΦΟΡΗΤΑ Η/Ζ	1	1	1	1	1	1	1							1	1	1	1	1	1	1	1	2	2	2	2	Διαθέσιμη	