

HΣ Ρόδου					Απολογισμός Λειτουργίας														Τρίτη, 3 Οκτώβριος 2023					
Αποδιδόμενη Ισχύς (MW)					14	14	10	10	18	18	18	17	21	18	26,5	17,1	17,1	17,1			17,1	17,1	17,1	17,1
Χρονική στιγμή	Πραγματικό Μέσο Όριο Φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Φ/Β (MW)	ΑΗΣ ΣΟΡΩΝΗΣ										ΘΗΣ Ν.ΡΟΔΟΥ									
					ATM 1	ATM 2	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7		
3/10/23 0:00	104,02	92,20	11,82	0,00	1	1			1		1							1	1	1	1		24,41	24,28
3/10/23 1:00	98,39	87,47	10,92	0,00	1	1			1		1							1	1	1	1		21,70	21,20
3/10/23 2:00	94,54	85,81	8,73	0,00	1	1			1		1							1		1	1		23,00	22,77
3/10/23 3:00	89,85	84,42	5,43	0,00	1	1			1		1							1		1	1		21,63	21,43
3/10/23 4:00	91,18	86,28	4,91	0,00	1	1					1							1	1	1	1		27,29	27,30
3/10/23 5:00	94,11	89,84	4,26	0,00	1	1					1							1	1	1	1		27,83	27,61
3/10/23 6:00	102,02	98,99	3,03	0,00	1	1					1					1		1	1	1	1		29,91	30,05
3/10/23 7:00	113,40	109,22	3,71	0,47	1	1					1					1		1	1	1	1		33,85	33,93
3/10/23 8:00	126,93	120,88	1,47	4,59	1	1					1					1		1	1	1	1	1	37,87	37,95
3/10/23 9:00	139,27	129,11	0,43	9,73	1	1					1					1		1	1	1	1	1	41,58	41,62
3/10/23 10:00	143,48	130,42	0,59	12,47	1	1					1			1	1			1	1	1	1	1	42,84	42,84
3/10/23 11:00	144,25	128,28	1,86	14,11	1	1					1			1	1			1	1	1	1	1	43,18	43,18
3/10/23 12:00	146,04	128,37	2,91	14,76	1	1					1			1	1			1	1	1	1	1	43,61	43,66
3/10/23 13:00	147,18	129,99	3,13	14,06	1	1					1			1	1			1	1	1	1	1	43,97	43,96
3/10/23 14:00	146,74	126,29	7,06	13,39	1	1					1			1	1			1	1	1	1	1	43,97	43,92
3/10/23 15:00	141,26	120,81	8,22	12,22	1	1					1		1	1	1	1		1		1			42,29	42,25
3/10/23 16:00	141,17	122,29	8,40	10,48	1	1					1		1	1	1	1		1	1	1	1		42,22	42,18
3/10/23 17:00	142,70	127,71	8,66	6,34	1	1					1			1	1			1	1	1	1	1	42,55	42,57
3/10/23 18:00	144,84	136,43	7,47	0,95	1	1					1			1	1			1	1	1	1	1	43,31	43,34
3/10/23 19:00	150,66	142,59	8,07	0,00	1	1					1			1	1			1	1	1	1	1	45,02	45,04
3/10/23 20:00	146,70	138,99	7,71	0,00	1	1					1			1	1			1	1	1	1	1	44,00	43,94
3/10/23 21:00	135,73	132,03	3,71	0,00	1	1					1			1	1			1	1	1	1	1	40,53	40,48
3/10/23 22:00	123,53	121,05	2,48	0,00	1	1					1			1	1			1	1	1	1	1	36,87	36,79
3/10/23 23:00	111,81	109,43	2,39	0,00	1	1					1			1	1			1	1	1	1	1	32,56	32,46

Μη διαθέσιμότητα μονάδας λόγω συντήρησης

Μη διαθέσιμότητα μονάδας λόγω βλάβης

Παρατηρήσεις

1. Λειτουργία AEP No2, No3, No4 λόγω καταιγίδων στη Νότια Ρόδο (14:00-16:00).