

HΣ Ρόδου					Απολογισμός Λειτουργίας														Κυριακή, 3 Δεκέμβριος 2023						
Αποδιδόμενη Ισχύς (MW)					14	14	10	10	18	18	18	17	21	18	26,5	17,1	17,1	17,1			17,1	17,1	17,1	17,1	
Χρονική στιγμή	Πραγματικό Μέσο Όριο Φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Φ/Β (MW)	ΑΗΣ ΣΟΡΩΝΗΣ										ΘΗΣ Ν.ΡΟΔΟΥ										
					ATM 1	ATM 2	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7			
3/12/23 0:00	48,04	36,30	11,75	0,00	1													1	1		1			22,01	13,81
3/12/23 1:00	44,00	34,02	9,98	0,00	1													1	1		1			14,64	10,19
3/12/23 2:00	42,42	34,22	8,21	0,00	1													1	1		1			9,00	8,41
3/12/23 3:00	40,69	33,90	6,79	0,00	1													1	1		1			6,62	6,75
3/12/23 4:00	40,27	34,27	5,99	0,00	1													1	1		1			5,08	6,14
3/12/23 5:00	41,04	34,92	6,12	0,00	1													1	1		1			5,95	6,84
3/12/23 6:00	42,80	34,89	7,91	0,00	1													1	1		1			8,28	8,82
3/12/23 7:00	44,18	34,50	9,46	0,22	1													1	1		1			10,89	10,07
3/12/23 8:00	47,38	34,58	10,92	1,88	1													1	1		1			12,76	11,72
3/12/23 9:00	52,80	35,27	12,41	5,12	1													1	1		1			15,65	13,82
3/12/23 10:00	55,51	35,68	14,32	5,50	1													1	1		1			18,84	15,96
3/12/23 11:00	58,11	37,04	14,08	6,99	1													1	1		1			19,71	17,08
3/12/23 12:00	60,07	40,44	11,10	8,53	1													1	1		1			19,95	17,58
3/12/23 13:00	59,32	42,06	10,89	6,37	1													1	1		1			18,48	17,76
3/12/23 14:00	58,45	44,12	9,01	5,32	1													1	1		1			17,98	17,44
3/12/23 15:00	57,18	46,72	7,59	2,86	1													1	1		1			17,08	17,08
3/12/23 16:00	58,70	49,24	8,90	0,57	1													1	1		1			18,28	17,53
3/12/23 17:00	65,30	55,48	9,82	0,00	1													1	1		1	1		19,96	19,50
3/12/23 18:00	67,46	54,49	12,97	0,00	1													1	1		1	1		22,49	20,22
3/12/23 19:00	67,91	55,13	12,79	0,00	1													1	1		1	1		21,54	20,29
3/12/23 20:00	66,07	56,14	9,93	0,00	1													1	1		1	1		19,87	19,74
3/12/23 21:00	62,92	51,77	11,15	0,00	1													1	1		1	1		19,51	18,82
3/12/23 22:00	57,27	46,35	10,93	0,00	1														1		1	1		20,26	17,13
3/12/23 23:00	52,10	39,64	12,46	0,00	1														1		1	1		19,55	15,55

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης