

Πέμπτη, 18 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σκύρου																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,251	1,206	1,180	1,149	1,128	1,190	1,274	1,396	1,542	1,561	1,539	1,523	1,429	1,460	1,368	1,335	1,402	1,663	1,809	1,838	1,784	1,699	1,533	1,345	34,60
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G3 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1									Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1																		1	1	1	1	1	1	1	Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G1 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1						Διαθέσιμη

Παρασκευή, 19 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σκύρου																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,254	1,162	1,128	1,089	1,089	1,115	1,220	1,400	1,500	1,480	1,365	1,260	1,277	1,257	1,228	1,164	1,215	1,465	1,676	1,726	1,670	1,591	1,450	1,310	32,09
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G3 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1																Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	1,1																				1	1	1	1	1	Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G1 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1						Διαθέσιμη

Σάββατο, 20 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σκύρου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,197	1,131	1,068	1,071	1,045	1,108	1,151	1,246	1,338	1,396	1,433	1,536	1,647	1,813	1,694	1,555	1,575	1,742	1,908	1,888	1,856	1,742	1,649	1,510	35,30	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G3 (MITSUBISHI S16R-PTA)	1,1																				1	1	1	1	1	Διαθέσιμη	
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1																Διαθέσιμη	
G5 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G6 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη		
G7 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G1 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1						Διαθέσιμη	



Δευτέρα, 22 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σκύρου																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,384	1,301	1,262	1,229	1,256	1,291	1,410	1,653	1,814	1,913	1,977	2,051	2,074	2,041	1,927	1,854	1,854	2,015	2,074	2,095	2,058	1,907	1,765	1,534	41,74
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G3 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1															Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1,1										1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1													1	1	1					1	1	1	1	1	Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G1 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1						Διαθέσιμη

Τρίτη, 23 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σκύρου																								
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,358	1,275	1,251	1,208	1,226	1,266	1,371	1,543	1,777	1,924	2,004	1,923	1,975	1,977	1,890	1,822	1,726	1,901	2,120	2,151	2,145	1,995	1,797	1,543	41,17
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G2 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G3 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1																Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1	Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G1 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1						Διαθέσιμη

Τετάρτη, 24 Ιανουάριος 2024		Απολογισμός λειτουργίας ΗΣ Σκύρου																									
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)	
Ζήτηση (MWh)		1,393	1,330	1,265	1,257	1,242	1,300	1,385	1,613	1,804	1,945	1,961	1,894	1,945	1,836	1,809	1,900	1,761	1,850	2,043	2,077	2,140	1,975	1,751	1,516	40,99	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G2 (MITSUBISHI S16R-PTA)	-																										Συντήρηση
G3 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1	Διαθέσιμη	
G4 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1																Διαθέσιμη	
G5 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G6 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G7 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη	
G1 (MITSUBISHI S16R-PTA)	1,1									1	1	1	1	1	1	1	1	1	1	1	1	1				Διαθέσιμη	