

HΣ Ρόδου					Απολογισμός Λειτουργίας																	Κυριακή, 10 Μάρτιος 2024			
Αποδιδόμενη Ισχύς (MW)					14	14	10	10	18	18	18	17	21	18	26,5	17,1	17,1	17,1	17,1	17,1	17,1			17,1	
Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Φ/Β (MW)	ΑΗΣ ΣΟΡΩΝΗΣ										ΘΗΣ Ν.ΡΟΔΟΥ										
					ATM 1	ATM 2	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7			
10/3/24 0:00	53,05	37,07	15,88	0,10	1											1						1	1	18,91	15,87
10/3/24 1:00	48,69	34,08	14,52	0,10	1											1						1	1	17,08	14,54
10/3/24 2:00	47,38	33,19	14,08	0,10	1											1						1	1	16,51	14,15
10/3/24 3:00	45,19	32,22	12,87	0,10	1											1						1	1	14,89	12,92
10/3/24 4:00	43,76	32,26	11,41	0,10	1											1						1	1	13,02	11,50
10/3/24 5:00	44,14	33,04	11,00	0,10	1											1						1	1	13,18	11,75
10/3/24 6:00	46,11	33,44	12,58	0,10	1											1						1	1	16,33	13,68
10/3/24 7:00	47,77	32,91	13,84	1,02	1											1						1	1	17,95	14,25
10/3/24 8:00	50,56	32,51	14,45	3,60	1											1						1	1	18,17	14,75
10/3/24 9:00	54,53	33,23	14,51	6,80	1											1						1	1	18,60	15,62
10/3/24 10:00	58,39	33,29	15,84	9,27	1											1						1	1	22,84	17,03
10/3/24 11:00	61,37	32,73	16,64	12,00	1											1						1	1	25,57	17,35
10/3/24 12:00	61,01	32,30	16,71	12,00	1											1						1	1	22,53	16,98
10/3/24 13:00	63,09	32,79	14,84	15,47	1											1						1	1	20,29	15,63
10/3/24 14:00	58,34	31,67	10,67	16,00	1											1						1	1	12,46	10,35
10/3/24 15:00	56,69	33,66	7,80	15,23	1											1						1	1	8,69	9,14
10/3/24 16:00	57,21	40,63	7,38	9,20	1											1						1	1	16,55	15,38
10/3/24 17:00	60,30	42,71	13,76	3,83	1											1						1	1	24,63	17,99
10/3/24 18:00	68,35	50,00	18,14	0,21	1											1						1	1	26,79	20,44
10/3/24 19:00	75,86	59,93	15,92	0,01	1											1	1					1	1	24,25	22,74
10/3/24 20:00	77,50	60,41	17,08	0,01	1											1	1					1	1	26,62	23,22
10/3/24 21:00	72,63	60,38	12,24	0,01	1											1	1					1	1	23,55	21,76
10/3/24 22:00	66,40	58,77	7,62	0,01	1											1	1					1	1	19,96	19,89
10/3/24 23:00	59,51	54,24	5,27	0,01	1											1	1					1	1	17,76	17,71

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

Παρατηρήσεις