

HΣ Ρόδου					Απολογισμός Λειτουργίας																	Σάββατο, 30 Μάρτιος 2024		
Αποδιδόμενη Ισχύς (MW)					14	14	10	10	18	18	18	17	21	18	26,5	17,1	17,1	17,1	17,1	17,1	17,1			17,1
Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Φ/Β (MW)	ΑΗΣ ΣΟΡΩΝΗΣ										ΘΗΣ Ν.ΡΟΔΟΥ									
					ATM 1	ATM 2	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7		
30/3/24 0:00	49,82	43,80	6,02	0,00	1													1		1		1	14,92	14,90
30/3/24 1:00	46,57	41,56	5,01	0,00	1													1		1		1	13,92	13,92
30/3/24 2:00	45,29	39,32	5,97	0,00	1													1		1		1	13,17	13,13
30/3/24 3:00	44,47	40,26	4,21	0,00	1													1		1		1	11,99	12,00
30/3/24 4:00	44,17	42,54	1,63	0,00	1													1		1		1	11,95	11,93
30/3/24 5:00	45,45	43,54	1,91	0,00	1													1		1		1	13,16	13,17
30/3/24 6:00	47,50	45,22	1,15	1,13	1													1		1		1	13,89	13,91
30/3/24 7:00	53,98	46,37	1,22	6,39	1													1		1		1	15,40	15,40
30/3/24 8:00	59,76	48,08	0,41	11,27	1													1		1		1	16,34	16,38
30/3/24 9:00	64,14	49,48	0,11	14,55	1													1		1		1	17,50	17,55
30/3/24 10:00	65,95	49,61	0,01	16,33	1													1		1		1	17,63	17,65
30/3/24 11:00	66,64	49,23	0,03	17,38	1													1		1		1	17,19	17,19
30/3/24 12:00	67,34	49,50	0,01	17,83	1													1		1		1	17,50	17,45
30/3/24 13:00	67,28	49,80	0,14	17,34	1													1		1		1	17,78	17,84
30/3/24 14:00	65,70	49,09	0,44	16,17	1													1		1		1	17,04	17,11
30/3/24 15:00	63,48	49,12	0,59	13,77	1													1		1		1	17,19	17,18
30/3/24 16:00	63,02	53,39	0,09	9,54	1													1		1		1	16,23	13,06
30/3/24 17:00	61,71	58,44	0,00	3,28	1				1									1		1		1	12,33	12,45
30/3/24 18:00	64,83	64,58	0,10	0,15	1				1									1		1		1	18,05	18,12
30/3/24 19:00	68,82	68,50	0,32	0,00	1				1									1		1	1	1	15,99	15,59
30/3/24 20:00	66,83	66,66	0,17	0,00	1				1									1		1	1	1	13,45	13,39
30/3/24 21:00	62,35	62,31	0,03	0,00	1													1		1	1	1	14,62	14,72
30/3/24 22:00	57,55	57,55	0,00	0,00	1													1		1	1	1	17,19	17,16
30/3/24 23:00	53,09	53,08	0,00	0,00	1													1		1	1	1	13,79	13,78

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

Παρατηρήσεις