

Παρασκευή, 7 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σκύρου																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,617	1,547	1,498	1,460	1,430	1,424	1,429	1,603	1,784	1,899	1,926	1,981	1,971	2,069	2,059	1,860	1,745	1,779	1,969	2,059	2,117	2,203	2,026	1,896	43,35
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1										1	1	1	1	1	1	1									Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1,1																			1	1	1	1	1	1	Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G5 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη

Τρίτη, 11 Ιούνιος 2024		Απολογισμός λειτουργίας ΗΣ Σκύρου																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,800	1,650	1,591	1,530	1,508	1,525	1,582	1,832	2,034	2,150	2,288	2,272	2,375	2,501	2,281	2,117	2,049	2,112	2,265	2,351	2,471	2,565	2,387	2,167	49,40
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MITSUBISHI S16R-PTA)	1									1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G2 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1																	Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1,1																					1	1	1	1	Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	-																									Συντήρηση
G5 (MITSUBISHI S16R-PTA)	1,1																									Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	1,1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	1								1	1	1	1	1	1	1	1	1	1	1	1	1					Διαθέσιμη

