

ΗΣ ΚΩ-ΚΑΛΥΜΝΟΥ		Απολογιστική Λειτουργία για την Προηγούμενη Ημέρα														Κυριακή, 16 Ιουνίου 2024													
		Αποδιδόμενη Ισχύς (MW)						9,000	11,000	11,000	11,000	16,000	16,000	11,000	11,500	23,100	1,500	1,300	1,300	5,000	5,000	5,000	7,300						
		ΤΕ (MW)						5,360	5,452	5,452	5,452	8,250	8,250	5,000	0,000	0,000	0,000	0,640	0,922	0,922	2,900	2,900	2,900	4,125					
Η Ρ Ε Ρ Ε	Χρονική στιγμή	Πραγματικό Μέσο όριο φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Παραγωγή ΥΒΣ Τήλου (MW)	ΑΣΠ Κω						ΑΣΠ Καλύμνου						Στρεφόμενη εφεδρεία (MW)	Εντολή περιορισμού των Αιολικών Πάρκων (MW)	Μέγιστη δυνατότητα απορρόφησης Αιολικής Παραγωγής (MW)	Μέση φόρτιση Μονάδων ΑΣΠ (% επί της αποδιδόμενης)	Κόστος καυσίμου (€)							
						61	62	63	64	65	66	A/Σ 67	A/Σ 632	A/Σ 633	A/Σ Ενοικ.	HTU 9-11	61						62	63	64	65	66		
Κυριακή, 16 Ιουνίου 2024	00:00	64,78	54,68	9,69	0,41	1	1		1	1	1									1	1			25,62	15,20	15,20	68%	7.079	
	01:00	60,68	51,63	8,73	0,32	1	1		1	1	1									1	1			23,67	15,20	15,20	69%	6.095	
	02:00	57,75	49,29	8,15	0,32	1	1		1	1	1									1	1			26,01	15,20	15,20	65%	5.848	
	03:00	55,85	47,41	8,08	0,36	1	1		1	1	1									1	1			27,89	15,20	15,20	63%	5.651	
	04:00	55,18	45,92	8,93	0,32	1	1		1	1	1									1	1			29,38	15,17	15,17	61%	5.496	
	05:00	55,57	46,47	8,79	0,30	1	1		1	1	1									1	1			28,83	15,19	15,19	62%	5.553	
	06:00	56,79	47,74	8,75	0,30	1	1		1	1	1									1	1			27,56	15,20	15,20	63%	5.686	
	07:00	61,64	51,45	9,86	0,33	1	1		1	1	1									1	1			23,85	15,20	15,20	68%	6.076	
	08:00	65,35	55,31	9,72	0,32	1	1		1	1	1									1	1			43,09	15,20	15,20	56%	11.147	
	09:00	67,18	58,95	7,91	0,32	1	1		1	1	1									1	1			39,45	15,20	15,20	60%	11.365	
	10:00	67,56	59,84	7,41	0,31	1	1		1	1	1									1	1			38,56	15,20	15,20	61%	11.500	
	11:00	66,87	56,85	9,62	0,40	1	1		1	1	1									1	1			41,55	15,20	15,20	58%	11.044	
	12:00	68,22	58,04	9,77	0,41	1	1		1	1	1									1	1			40,36	15,20	15,20	59%	11.226	
	13:00	69,24	60,59	8,12	0,54	1	1		1	1	1									1	1			37,81	15,20	15,20	62%	11.613	
	14:00	69,02	58,16	10,32	0,53	1	1		1	1	1									1	1			40,24	15,20	15,20	59%	11.244	
	15:00	67,87	57,92	9,28	0,67	1	1		1	1	1									1	1			40,48	15,20	15,20	59%	11.208	
	16:00	69,41	60,17	8,82	0,41	1	1		1	1	1									1	1			38,23	15,20	15,20	61%	11.550	
	17:00	74,26	63,72	10,14	0,40	1	1		1	1	1									1	1			34,68	15,20	15,20	65%	12.084	
	18:00	78,96	68,82	9,73	0,40	1	1		1	1	1									1	1			34,58	15,20	15,20	67%	13.359	
	19:00	80,56	69,97	10,18	0,41	1	1		1	1	1									1	1			33,43	15,20	15,20	68%	13.529	
	20:00	79,90	70,03	9,46	0,40	1	1		1	1	1									1	1			33,37	15,20	15,20	68%	13.537	
	21:00	78,87	69,67	8,80	0,40	1	1		1	1	1									1	1			33,73	15,20	15,20	67%	13.482	
	22:00	73,46	64,23	8,84	0,38	1	1		1	1	1									1	1			39,17	15,20	15,20	62%	12.642	
23:00	68,20	59,67	8,15	0,38	1	1		1	1	1									1	1			38,73	15,20	15,20	61%	12.021		
		1613,17 MWh																				ΑΩΛ: 24,00					240.036 €		

**Παρατηρήσεις:**

Δεν προτείνεται οποιαδήποτε αλλαγή στην απολογιστική λειτουργία. Η G5 του ΑΣΠ Καλύμνου λειτουργεί σε ισχύ έως 4,2MW.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
Μη διαθεσιμότητα μονάδας λόγω βλάβης