

HΣ Ρόδου					Απολογισμός Λειτουργίας														Σάββατο, 22 Ιούνιος 2024					
Αποδιδόμενη Ισχύς (MW)					14	14	10	10	18	18	18	17	21	18	26,5	17,1	17,1	17,1			17,1	17,1	17,1	17,1
Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Φ/Β (MW)	ΑΗΣ ΣΟΡΩΝΗΣ									ΘΗΣ Ν.ΡΟΔΟΥ										
					ΑΤΜ 1	ΑΤΜ 2	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	ΑΕΡ 1	ΑΕΡ 2	ΑΕΡ 3	ΑΕΡ 4	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7		
22/6/24 0:00	151,66	132,12	19,54	0,00	1				1	1	1					1	1	1	1	1	1		45,55	45,39
22/6/24 1:00	143,02	118,86	24,16	0,00	1				1	1	1					1	1	1		1	1		46,45	42,82
22/6/24 2:00	137,48	108,44	29,05	0,00	1				1	1	1					1		1		1	1		48,30	41,17
22/6/24 3:00	133,63	106,36	27,26	0,00	1				1	1	1					1		1		1	1		48,52	40,01
22/6/24 4:00	131,11	107,71	23,40	0,00	1				1	1	1					1		1		1	1		43,82	39,28
22/6/24 5:00	131,51	111,59	19,91	0,00	1				1	1	1					1		1		1	1		39,78	39,36
22/6/24 6:00	136,83	115,12	20,42	1,28	1				1	1	1					1	1	1		1	1		41,24	40,82
22/6/24 7:00	155,26	128,25	21,29	5,72	1				1	1	1	1				1	1	1		1	1		46,42	46,52
22/6/24 8:00	172,53	141,55	20,51	10,47	1				1	1	1	1				1	1	1		1	1	1	48,55	48,55
22/6/24 9:00	187,35	152,93	20,60	13,82	1				1	1	1	1				1	1	1		1	1	1	48,55	48,55
22/6/24 10:00	194,12	161,15	16,57	16,40	1				1	1	1	1				1	1	1	1	1	1	1	48,55	48,55
22/6/24 11:00	197,26	158,22	20,53	18,50	1				1	1	1	1				1	1	1	1	1	1	1	48,55	48,55
22/6/24 12:00	202,35	161,63	21,55	19,17	1				1	1	1	1				1	1	1	1	1	1	1	48,55	48,55
22/6/24 13:00	209,14	166,46	23,35	19,33	1				1	1	1	1				1	1	1	1	1	1	1	48,55	48,55
22/6/24 14:00	209,64	168,01	22,78	18,85	1				1	1	1	1				1	1	1	1	1	1	1	48,55	48,55
22/6/24 15:00	206,85	165,73	23,30	17,82	1				1	1	1	1				1	1	1	1	1	1	1	48,55	48,55
22/6/24 16:00	207,82	166,47	25,37	15,98	1				1	1	1	1				1	1	1	1	1	1	1	48,55	48,55
22/6/24 17:00	208,90	167,30	28,43	13,17	1				1	1	1	1		1		1	1	1	1	1	1	1	48,55	48,55
22/6/24 18:00	209,58	173,79	26,86	8,93	1				1	1	1	1		1		1	1	1	1	1	1	1	48,55	48,55
22/6/24 19:00	202,01	174,04	25,48	2,49	1				1	1	1	1		1		1	1	1	1	1	1	1	48,55	48,55
22/6/24 20:00	193,60	166,62	26,89	0,09	1				1	1	1	1		1		1	1	1	1	1	1	1	48,55	48,55
22/6/24 21:00	186,87	158,57	28,30	0,00	1				1	1	1	1		1		1	1	1	1	1	1	1	48,55	48,55
22/6/24 22:00	174,66	147,65	27,00	0,00	1				1	1	1	1				1	1	1	1	1	1	1	48,55	48,55
22/6/24 23:00	161,79	135,66	26,13	0,00	1				1	1	1	1				1	1	1	1	1	1		48,53	48,07

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
Μη διαθεσιμότητα μονάδας λόγω βλάβης

Παρατηρήσεις