







Σάββατο, 6 Ιούλιος 2024		Απολογισμός λειτουργίας ΗΣ Σερίφου																								
Ώρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23	ΣΥΝΟΛΟ (MWh)
Ζήτηση (MWh)		1,610	1,453	1,341	1,296	1,257	1,252	1,278	1,367	1,453	1,594	1,697	1,692	1,695	1,726	1,753	1,765	1,816	1,899	2,014	2,110	2,121	2,061	1,978	1,820	40,05
Μονάδα	Αποδιδόμενη Ισχύς (MW)																									
G1 (MWM TBD603V12)	0,3																									Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	0,85	1	1	1	1	1	1	1	1	1								1	1	1	1					Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	0,85																									Διαθέσιμη
G5 (MITSUBISHI S16R-PTA)	0,85																									Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	0,85														1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
G7 (MITSUBISHI S16R-PTA)	0,85																									Διαθέσιμη
G10 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη
Μισθωμένη ισχύς	1	1									1	1	1	1	1	1	1					1	1	1	1	Διαθέσιμη





