

ΗΣ ΘΗΡΑΣ		Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα					Δευτέρα 26/8/2024				
		Αποδιδόμενη Ισχύς (MW)	7,3	6	3,5	3,5	3,5	5,8	10,5	8,5	1
Ημέρα	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G6	G8	G30	G29	H/Z (x50)
Δευτέρα	26/08/24 0:00	47,85	1	1	1	1	1	1	1	1	15
	26/08/24 1:00	44,38	1	1	1	1	1	1	1	1	9
	26/08/24 2:00	41,77	1	1	1	1	1	1	1	1	9
	26/08/24 3:00	40,62	1	1	1	1	1	1	1	1	9
	26/08/24 4:00	39,68	1	1	1	1	1	1	1	1	9
	26/08/24 5:00	39,46	1	1	1	1	1	1	1	1	9
	26/08/24 6:00	43,55	1	1	1	1	1	1	1	1	15
	26/08/24 7:00	47,86	1	1	1	1	1	1	1	1	20
	26/08/24 8:00	53,03	1	1	1	1	1	1	1	1	26
	26/08/24 9:00	56,26	1	1	1	1	1	1	1	1	26
	26/08/24 10:00	59,53	1	1	1	1	1	1	1	1	26
	26/08/24 11:00	61,27	1	1	1	1	1	1	1	1	26
	26/08/24 12:00	63,44	1	1	1	1	1	1	1	1	30
	26/08/24 13:00	63,51	1	1	1	1	1	1	1	1	30
	26/08/24 14:00	63,05	1	1	1	1	1	1	1	1	30
	26/08/24 15:00	61,05	1	1	1	1	1	1	1	1	30
	26/08/24 16:00	60,95	1	1	1	1	1	1	1	1	30
	26/08/24 17:00	59,89	1	1	1	1	1	1	1	1	30
	26/08/24 18:00	57,71	1	1	1	1	1	1	1	1	30
	26/08/24 19:00	58,39	1	1	1	1	1	1	1	1	30
26/08/24 20:00	59,44	1	1	1	1	1	1	1	1	30	
26/08/24 21:00	57,49	1	1	1	1	1	1	1	1	26	
26/08/24 22:00	53,80	1	1	1	1	1	1	1	1	26	
26/08/24 23:00	50,08	1	1	1	1	1	1	1	1	20	
<u>Παρατηρήσεις:</u>											
Στον ΑΣΠ βρίσκονται 34MW μισθωμένης ισχύος. Δύο φορητά ΗΖ βρίσκονται σε βλάβη.											
Μη διαθεσιμότητα μονάδας λόγω συντήρησης.											
Μη διαθεσιμότητα μονάδας λόγω βλάβης.											