

Κυριακή, 15 Σεπτέμβριος 2024		Προτεινόμενος ΗΕΠ Σερίφου																							ΣΥΝΟΛΟ (MWh)		
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23		
Εκτίμηση ζήτησης (MWh)		1,805	1,701	1,610	1,563	1,520	1,525	1,513	1,492	1,596	1,728	1,767	1,782	1,767	1,874	1,865	1,788	1,759	1,791	1,848	1,954	2,029	1,829	1,698	1,550	41,35	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MWM TBD603V12)	0,4																										Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G5 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G7 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
G10 (MITSUBISHI S16R-PTA)	1	1	1	1							1	1	1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη	

Τετάρτη, 18 Σεπτέμβριος 2024		Προτεινόμενος ΗΕΠ Σερίφου																							ΣΥΝΟΛΟ (MWh)		
Ωρες Κατανομής		00	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16	17	18	19	20	21	22	23		
Εκτίμηση ζήτησης (MWh)		1,436	1,353	1,283	1,235	1,212	1,202	1,199	1,240	1,427	1,551	1,590	1,603	1,619	1,645	1,647	1,642	1,634	1,701	1,775	1,879	1,983	1,893	1,773	1,605	37,13	
Μονάδα	Αποδιδόμενη Ισχύς (MW)																										
G1 (MWM TBD603V12)	0,4																										Διαθέσιμη
G3 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
G4 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G5 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
G6 (MITSUBISHI S16R-PTA)	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	Διαθέσιμη	
G7 (MITSUBISHI S16R-PTA)	1																										Διαθέσιμη
G10 (MITSUBISHI S16R-PTA)	1												1	1	1	1	1	1	1	1	1	1	1	1		Διαθέσιμη	