

| ΗΣ ΘΗΡΑΣ | | Προτεινόμενος ΗΕΠ για την Επόμενη Ημέρα | | | | Τρίτη 24/9/2024 | | | | | |
|----------------|----------------|---|-----|-----|-----|-----------------|-----|-----|------|-----|-----------|
| | | Αποδιδόμενη Ισχύς (MW) | 7,3 | 7,3 | 3,5 | 3,5 | 3,5 | 5,8 | 10,5 | 8,5 | 1 |
| Ημέρα | Χρονική στιγμή | Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW) | G1 | G2 | G3 | G4 | G6 | G8 | G30 | G29 | H/Z (x50) |
| Τρίτη | 24/09/24 0:00 | 37,72 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 15 |
| | 24/09/24 1:00 | 34,94 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 9 |
| | 24/09/24 2:00 | 34,21 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 9 |
| | 24/09/24 3:00 | 31,41 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 9 |
| | 24/09/24 4:00 | 30,95 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 9 |
| | 24/09/24 5:00 | 31,38 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 9 |
| | 24/09/24 6:00 | 37,85 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 10 |
| | 24/09/24 7:00 | 42,75 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 12 |
| | 24/09/24 8:00 | 45,26 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 12 |
| | 24/09/24 9:00 | 48,46 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 15 |
| | 24/09/24 10:00 | 49,30 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 |
| | 24/09/24 11:00 | 49,50 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 |
| | 24/09/24 12:00 | 50,07 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 |
| | 24/09/24 13:00 | 51,05 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 |
| | 24/09/24 14:00 | 51,82 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 |
| | 24/09/24 15:00 | 50,21 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 |
| | 24/09/24 16:00 | 49,38 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 |
| | 24/09/24 17:00 | 49,96 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 |
| | 24/09/24 18:00 | 50,19 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 |
| | 24/09/24 19:00 | 51,90 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 |
| 24/09/24 20:00 | 50,15 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 | |
| 24/09/24 21:00 | 47,30 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 20 | |
| 24/09/24 22:00 | 43,25 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 15 | |
| 24/09/24 23:00 | 40,93 | 1 | | 1 | 1 | 1 | 1 | 1 | 1 | 12 | |

Παρατηρήσεις:

Στον ΑΣΠ βρίσκονται 34MW μισθωμένης ισχύος. Δύο φορητά ΗΖ βρίσκονται σε βλάβη.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης.

Μη διαθεσιμότητα μονάδας λόγω βλάβης.