

ΗΣ Ρόδου					Απολογισμός Λειτουργίας																	Τετάρτη, 16 Οκτώβριος 2024	
Αποδιδόμενη Ισχύς (MW)					14	14	10	18	18	18	17	21	18	26,5	17,1	17,1	17,1	17,1	17,1	17,1	17,1		
Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	Θερμική Παραγωγή (MW)	Αιολική Παραγωγή (MW)	Φ/Β (MW)	ΑΗΣ ΣΟΡΩΝΗΣ								ΘΗΣ Ν.ΡΟΔΟΥ										
					ATM 1	ATM 2	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	AEP 1	AEP 2	AEP 3	AEP 4	DIESEL 1	DIESEL 2	DIESEL 3	DIESEL 4	DIESEL 5	DIESEL 6	DIESEL 7		
16/10/24 0:00	97,52	86,92	10,60	0,00	1	1	1		1						1		1		1	1		28,64	28,65
16/10/24 1:00	92,06	81,29	10,77	0,00	1	1	1		1						1		1		1	1		25,66	24,77
16/10/24 2:00	89,38	73,56	15,82	0,00	1	1	1		1						1		1			1		32,45	26,65
16/10/24 3:00	88,31	69,02	19,29	0,00	1	1	1		1						1		1			1		36,58	26,41
16/10/24 4:00	88,00	70,78	17,21	0,00	1	1	1		1						1		1			1		31,97	26,27
16/10/24 5:00	91,77	77,85	13,91	0,00	1	1	1		1						1		1			1		27,52	27,46
16/10/24 6:00	101,18	88,97	12,21	0,00	1	1	1		1						1		1		1	1		30,07	29,79
16/10/24 7:00	113,88	99,32	14,19	0,37	1	1	1	1	1						1		1		1	1		31,38	31,25
16/10/24 8:00	126,05	108,82	12,01	5,22	1	1	1	1	1						1		1		1	1		37,51	37,57
16/10/24 9:00	137,27	114,88	11,36	11,03	1	1	1	1	1						1		1		1	1		39,56	39,61
16/10/24 10:00	142,41	116,32	11,66	14,43	1	1	1	1	1						1		1		1	1		39,59	39,24
16/10/24 11:00	143,02	117,60	8,20	17,23	1	1	1	1	1						1		1		1	1		38,25	38,35
16/10/24 12:00	145,13	118,34	8,05	18,74	1	1	1	1	1						1		1		1	1		38,79	38,73
16/10/24 13:00	147,26	114,32	14,14	18,79	1	1	1	1	1						1		1		1	1		40,67	40,75
16/10/24 14:00	147,05	109,87	19,34	17,84	1	1	1	1	1						1		1		1	1		42,40	41,79
16/10/24 15:00	142,09	103,80	22,36	15,93	1	1	1	1	1						1		1		1	1		44,60	38,94
16/10/24 16:00	139,36	103,50	23,48	12,38	1	1	1	1	1						1		1		1	1		45,31	39,62
16/10/24 17:00	140,07	112,76	21,25	6,06	1	1	1	1	1						1		1		1	1		44,47	41,97
16/10/24 18:00	143,13	120,43	21,97	0,73	1	1	1	1	1						1		1		1	1		43,04	42,43
16/10/24 19:00	147,63	122,24	25,40	0,00	1	1	1	1	1	1					1		1		1	1		46,08	44,25
16/10/24 20:00	141,58	115,48	26,10	0,00	1	1	1	1	1	1					1		1		1	1		45,26	40,38
16/10/24 21:00	130,49	106,73	23,76	0,00	1	1	1	1	1	1					1		1		1	1		40,59	36,36
16/10/24 22:00	117,86	90,18	27,68	0,00	1	1	1		1						1		1		1	1		45,95	35,36
16/10/24 23:00	106,47	79,31	27,16	0,00	1	1	1		1						1		1		1	1		43,26	31,92

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

#### Παρατηρήσεις

1. Λειτουργία AEP No2 λόγω περιορισμένης χρήσης μονάδων ΘΗΣ λόγω καυσίμου.