

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ		Τετάρτη, 4 Δεκεμβρίου 2024				
Αποδιδόμενη Ισχύς (ΜW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G2	G3	G5	G8	G9
01:00	0,913	1						
02:00	0,876	1						
03:00	0,854	1						
04:00	0,850	1						
05:00	0,879	1						
06:00	0,908	1						
07:00	0,957	1						
08:00	0,991	1	1					
09:00	1,031	1	1					
10:00	1,073	1	1					
11:00	1,021	1	1					
12:00	1,001	1	1					
13:00	0,990	1	1					
14:00	1,013	1	1					
15:00	1,059	1	1					
16:00	1,138	1	1					
17:00	1,271	1	1					
18:00	1,349	1	1					
19:00	1,388	1	1					
20:00	1,375	1	1					
21:00	1,297	1	1					
22:00	1,195	1	1					
23:00	1,077	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ		Πέμπτη, 5 Δεκεμβρίου 2024				
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,919	1						
02:00	0,884	1						
03:00	0,865	1						
04:00	0,860	1						
05:00	0,868	1						
06:00	0,902	1						
07:00	0,951	1						
08:00	0,995	1	1					
09:00	1,034	1	1					
10:00	1,040	1	1					
11:00	1,035	1	1					
12:00	1,022	1	1					
13:00	1,015	1	1					
14:00	1,007	1	1					
15:00	1,079	1	1					
16:00	1,130	1	1					
17:00	1,266	1	1					
18:00	1,348	1	1					
19:00	1,403	1	1					
20:00	1,402	1	1					
21:00	1,321	1	1					
22:00	1,205	1	1					
23:00	1,072	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ		Παρασκευή, 6 Δεκεμβρίου 2024				
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ρ Ε Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,924	1						
02:00	0,885	1						
03:00	0,860	1						
04:00	0,854	1						
05:00	0,872	1						
06:00	0,909	1						
07:00	0,962	1						
08:00	1,023	1	1					
09:00	1,074	1	1					
10:00	1,050	1	1					
11:00	1,071	1	1					
12:00	1,040	1	1					
13:00	1,030	1	1					
14:00	1,037	1	1					
15:00	1,132	1	1					
16:00	1,203	1	1					
17:00	1,290	1	1					
18:00	1,358	1	1					
19:00	1,390	1	1					
20:00	1,387	1	1					
21:00	1,311	1	1					
22:00	1,192	1	1					
23:00	1,056	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ		Σάββατο, 7 Δεκεμβρίου 2024				
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ρ Ε Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,922	1						
02:00	0,889	1						
03:00	0,869	1						
04:00	0,863	1						
05:00	0,870	1						
06:00	0,899	1						
07:00	0,948	1						
08:00	1,002	1	1					
09:00	1,048	1	1					
10:00	1,078	1	1					
11:00	1,065	1	1					
12:00	1,059	1	1					
13:00	1,113	1	1					
14:00	1,106	1	1					
15:00	1,145	1	1					
16:00	1,203	1	1					
17:00	1,303	1	1					
18:00	1,364	1	1					
19:00	1,381	1	1					
20:00	1,380	1	1					
21:00	1,305	1	1					
22:00	1,186	1	1					
23:00	1,057	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 8 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,939	1						
02:00	0,897	1						
03:00	0,871	1						
04:00	0,863	1						
05:00	0,870	1						
06:00	0,903	1						
07:00	0,953	1						
08:00	1,011	1	1					
09:00	1,035	1	1					
10:00	1,056	1	1					
11:00	1,053	1	1					
12:00	1,050	1	1					
13:00	1,042	1	1					
14:00	1,041	1	1					
15:00	1,074	1	1					
16:00	1,126	1	1					
17:00	1,253	1	1					
18:00	1,325	1	1					
19:00	1,359	1	1					
20:00	1,365	1	1					
21:00	1,293	1	1					
22:00	1,162	1	1					
23:00	1,036	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ		Δευτέρα, 9 Δεκεμβρίου 2024				
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,897	1						
02:00	0,858	1						
03:00	0,838	1						
04:00	0,839	1						
05:00	0,862	1						
06:00	0,908	1						
07:00	0,963	1						
08:00	1,017	1	1					
09:00	1,035	1	1					
10:00	1,071	1	1					
11:00	1,076	1	1					
12:00	1,089	1	1					
13:00	1,082	1	1					
14:00	1,071	1	1					
15:00	1,092	1	1					
16:00	1,142	1	1					
17:00	1,274	1	1					
18:00	1,355	1	1					
19:00	1,398	1	1					
20:00	1,390	1	1					
21:00	1,314	1	1					
22:00	1,192	1	1					
23:00	1,065	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΑΜΟΡΓΟΥ		Προτεινόμενος ΗΕΠ		Τρίτη, 10 Δεκεμβρίου 2024				
Αποδιδόμενη Ισχύς (MW)		1,100	1,100	1,100	1,100	0,460	0,460	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G5	G8	G9
01:00	0,911	1						
02:00	0,879	1						
03:00	0,860	1						
04:00	0,856	1						
05:00	0,866	1						
06:00	0,904	1						
07:00	0,972	1						
08:00	1,045	1	1					
09:00	1,076	1	1					
10:00	1,110	1	1					
11:00	1,120	1	1					
12:00	1,109	1	1					
13:00	1,108	1	1					
14:00	1,119	1	1					
15:00	1,113	1	1					
16:00	1,179	1	1					
17:00	1,282	1	1					
18:00	1,356	1	1					
19:00	1,407	1	1					
20:00	1,404	1	1					
21:00	1,326	1	1					
22:00	1,208	1	1					
23:00	1,077	1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης