

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Παρασκευή, 6 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,339	1								
02:00	0,326	1								
03:00	0,320	1								
04:00	0,320	1								
05:00	0,327	1								
06:00	0,338	1								
07:00	0,356	1				1				
08:00	0,384	1				1				
09:00	0,407	1				1				
10:00	0,410	1				1				
11:00	0,403	1				1				
12:00	0,405	1				1				
13:00	0,418	1				1				
14:00	0,427	1				1				
15:00	0,428	1				1				
16:00	0,430	1				1				
17:00	0,448	1				1				
18:00	0,473	1				1				
19:00	0,490	1				1				
20:00	0,489	1				1				
21:00	0,468	1				1				
22:00	0,430	1				1				
23:00	0,384	1				1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Σάββατο, 7 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,343	1				1				
02:00	0,328	1								
03:00	0,320	1								
04:00	0,317	1								
05:00	0,321	1								
06:00	0,330	1								
07:00	0,348	1				1				
08:00	0,376	1				1				
09:00	0,403	1				1				
10:00	0,411	1				1				
11:00	0,406	1				1				
12:00	0,406	1				1				
13:00	0,417	1				1				
14:00	0,427	1				1				
15:00	0,423	1				1				
16:00	0,428	1				1				
17:00	0,446	1				1				
18:00	0,471	1				1				
19:00	0,488	1				1				
20:00	0,487	1				1				
21:00	0,466	1				1				
22:00	0,431	1				1				
23:00	0,385	1				1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Κυριακή, 8 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,345	1				1				
02:00	0,330	1								
03:00	0,320	1								
04:00	0,317	1								
05:00	0,319	1								
06:00	0,326	1								
07:00	0,342	1				1				
08:00	0,370	1				1				
09:00	0,399	1				1				
10:00	0,409	1				1				
11:00	0,403	1				1				
12:00	0,402	1				1				
13:00	0,411	1				1				
14:00	0,420	1				1				
15:00	0,424	1				1				
16:00	0,431	1				1				
17:00	0,448	1				1				
18:00	0,470	1				1				
19:00	0,484	1				1				
20:00	0,482	1				1				
21:00	0,462	1				1				
22:00	0,427	1				1				
23:00	0,382	1				1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Δευτέρα, 9 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,334	1								
02:00	0,319	1								
03:00	0,311	1								
04:00	0,312	1								
05:00	0,323	1								
06:00	0,339	1								
07:00	0,362	1				1				
08:00	0,384	1				1				
09:00	0,388	1				1				
10:00	0,375	1				1				
11:00	0,374	1				1				
12:00	0,395	1				1				
13:00	0,417	1				1				
14:00	0,424	1				1				
15:00	0,418	1				1				
16:00	0,418	1				1				
17:00	0,435	1				1				
18:00	0,463	1				1				
19:00	0,483	1				1				
20:00	0,484	1				1				
21:00	0,461	1				1				
22:00	0,419	1				1				
23:00	0,365	1				1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Τρίτη, 10 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,331	1								
02:00	0,317	1								
03:00	0,311	1								
04:00	0,314	1								
05:00	0,324	1								
06:00	0,339	1								
07:00	0,360	1				1				
08:00	0,383	1				1				
09:00	0,395	1				1				
10:00	0,388	1				1				
11:00	0,383	1				1				
12:00	0,398	1				1				
13:00	0,419	1				1				
14:00	0,424	1				1				
15:00	0,418	1				1				
16:00	0,415	1				1				
17:00	0,429	1				1				
18:00	0,455	1				1				
19:00	0,475	1				1				
20:00	0,475	1				1				
21:00	0,451	1				1				
22:00	0,409	1				1				
23:00	0,353	1				1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Τετάρτη, 11 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,330	1								
02:00	0,317	1								
03:00	0,311	1								
04:00	0,313	1								
05:00	0,322	1								
06:00	0,335	1								
07:00	0,355	1				1				
08:00	0,381	1				1				
09:00	0,399	1				1				
10:00	0,396	1				1				
11:00	0,391	1				1				
12:00	0,402	1				1				
13:00	0,420	1				1				
14:00	0,426	1				1				
15:00	0,421	1				1				
16:00	0,417	1				1				
17:00	0,428	1				1				
18:00	0,452	1				1				
19:00	0,471	1				1				
20:00	0,471	1				1				
21:00	0,449	1				1				
22:00	0,409	1				1				
23:00	0,357	1				1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Πέμπτη, 12 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,331	1								
02:00	0,317	1								
03:00	0,310	1								
04:00	0,311	1								
05:00	0,318	1								
06:00	0,329	1								
07:00	0,349	1				1				
08:00	0,378	1				1				
09:00	0,401	1				1				
10:00	0,403	1				1				
11:00	0,399	1				1				
12:00	0,407	1				1				
13:00	0,423	1				1				
14:00	0,429	1				1				
15:00	0,423	1				1				
16:00	0,419	1				1				
17:00	0,431	1				1				
18:00	0,455	1				1				
19:00	0,474	1				1				
20:00	0,475	1				1				
21:00	0,454	1				1				
22:00	0,416	1				1				
23:00	0,367	1				1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης