

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Παρασκευή, 27 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,400	1					1			
02:00	0,387	1					1			
03:00	0,380	1					1			
04:00	0,378	1					1			
05:00	0,389	1					1			
06:00	0,404	1					1			
07:00	0,416	1					1			
08:00	0,443	1					1			
09:00	0,467	1					1			
10:00	0,462	1					1			
11:00	0,457	1					1			
12:00	0,437	1					1			
13:00	0,449	1					1			
14:00	0,479	1					1			
15:00	0,495	1					1	1		
16:00	0,502	1					1	1		
17:00	0,540	1					1	1		
18:00	0,561	1					1	1		
19:00	0,563	1					1	1		
20:00	0,558	1					1	1		
21:00	0,536	1					1	1		
22:00	0,496	1					1	1		
23:00	0,448	1					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Σάββατο, 28 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
Σάββατο, 28 Δεκεμβρίου 2024	00:00	0,423	1					1		
	01:00	0,402	1					1		
	02:00	0,387	1					1		
	03:00	0,380	1					1		
	04:00	0,376	1					1		
	05:00	0,380	1					1		
	06:00	0,392	1					1		
	07:00	0,406	1					1		
	08:00	0,435	1					1		
	09:00	0,465	1					1		
	10:00	0,473	1					1		
	11:00	0,472	1					1		
	12:00	0,469	1					1		
	13:00	0,479	1					1		
	14:00	0,487	1					1		
	15:00	0,497	1					1	1	
	16:00	0,504	1					1	1	
	17:00	0,533	1					1	1	
	18:00	0,555	1					1	1	
	19:00	0,561	1					1	1	
	20:00	0,557	1					1	1	
	21:00	0,539	1					1	1	
	22:00	0,491	1					1		
	23:00	0,448	1					1		



Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Κυριακή, 29 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,405	1					1			
02:00	0,389	1					1			
03:00	0,379	1					1			
04:00	0,377	1					1			
05:00	0,379	1					1			
06:00	0,390	1					1			
07:00	0,403	1					1			
08:00	0,431	1					1			
09:00	0,458	1					1			
10:00	0,467	1					1			
11:00	0,454	1					1			
12:00	0,447	1					1			
13:00	0,464	1					1			
14:00	0,481	1					1			
15:00	0,490	1					1			
16:00	0,508	1					1	1		
17:00	0,534	1					1	1		
18:00	0,552	1					1	1		
19:00	0,561	1					1	1		
20:00	0,557	1					1	1		
21:00	0,537	1					1	1		
22:00	0,495	1					1	1		
23:00	0,449	1					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Δευτέρα, 30 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ρ Ε Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,392	1					1			
02:00	0,380	1					1			
03:00	0,373	1					1			
04:00	0,374	1					1			
05:00	0,383	1					1			
06:00	0,402	1					1			
07:00	0,420	1					1			
08:00	0,438	1					1			
09:00	0,435	1					1			
10:00	0,403	1					1			
11:00	0,409	1					1			
12:00	0,448	1					1			
13:00	0,473	1					1			
14:00	0,481	1					1			
15:00	0,482	1					1			
16:00	0,492	1					1			
17:00	0,517	1					1	1		
18:00	0,544	1					1	1		
19:00	0,559	1					1	1		
20:00	0,556	1					1	1		
21:00	0,530	1					1	1		
22:00	0,485	1					1			
23:00	0,431	1					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Τρίτη, 31 Δεκεμβρίου 2024			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,391	1					1			
02:00	0,375	1					1			
03:00	0,366	1					1			
04:00	0,364	1					1			
05:00	0,366	1					1			
06:00	0,377	1					1			
07:00	0,400	1					1			
08:00	0,431	1					1			
09:00	0,448	1					1			
10:00	0,448	1					1			
11:00	0,456	1					1			
12:00	0,457	1					1			
13:00	0,467	1					1			
14:00	0,462	1					1			
15:00	0,458	1					1			
16:00	0,456	1					1			
17:00	0,485	1					1			
18:00	0,510	1					1	1		
19:00	0,526	1					1	1		
20:00	0,534	1					1	1		
21:00	0,505	1					1	1		
22:00	0,472	1					1			
23:00	0,430	1					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Τετάρτη, 1 Ιανουαρίου 2025			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,387	1					1			
02:00	0,371	1					1			
03:00	0,357	1					1			
04:00	0,355	1					1			
05:00	0,358	1					1			
06:00	0,370	1					1			
07:00	0,392	1					1			
08:00	0,424	1					1			
09:00	0,446	1					1			
10:00	0,433	1					1			
11:00	0,402	1					1			
12:00	0,422	1					1			
13:00	0,445	1					1			
14:00	0,452	1					1			
15:00	0,453	1					1			
16:00	0,456	1					1			
17:00	0,487	1					1			
18:00	0,518	1					1	1		
19:00	0,536	1					1	1		
20:00	0,542	1					1	1		
21:00	0,530	1					1	1		
22:00	0,493	1					1	1		
23:00	0,445	1					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΜΕΓΙΣΤΗΣ		Προτεινόμενος ΗΕΠ					Πέμπτη, 2 Ιανουαρίου 2025			
Αποδιδόμενη Ισχύς (MW)		0,400	0,400	0,400	0,250	0,200	0,220	0,220	0,400	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G2	G3	G4	G5	G6	G7	G8
01:00	0,382	1					1			
02:00	0,368	1					1			
03:00	0,355	1					1			
04:00	0,350	1					1			
05:00	0,352	1					1			
06:00	0,362	1					1			
07:00	0,383	1					1			
08:00	0,415	1					1			
09:00	0,438	1					1			
10:00	0,441	1					1			
11:00	0,438	1					1			
12:00	0,438	1					1			
13:00	0,448	1					1			
14:00	0,455	1					1			
15:00	0,453	1					1			
16:00	0,458	1					1			
17:00	0,485	1					1			
18:00	0,515	1					1	1		
19:00	0,536	1					1	1		
20:00	0,543	1					1	1		
21:00	0,534	1					1	1		
22:00	0,499	1					1	1		
23:00	0,454	1					1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης