

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Πέμπτη, 12 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
	Πέμπτη, 12 Δεκεμβρίου 2024	00:00	1,285			1			1
01:00		1,207			1			1	
02:00		1,188			1			1	
03:00		1,141			1			1	
04:00		1,132			1			1	
05:00		1,175			1			1	
06:00		1,311			1			1	
07:00		1,495			1			1	
08:00		1,536			1			1	
09:00		1,498			1			1	
10:00		1,517			1			1	
11:00		1,535			1			1	
12:00		1,588			1			1	
13:00		1,647			1			1	
14:00		1,600			1			1	
15:00		1,402			1			1	
16:00		1,521			1			1	
17:00		1,773			1			1	
18:00		1,901			1			1	
19:00		1,896			1			1	
20:00		1,949			1			1	
21:00		1,815			1			1	
22:00		1,638			1			1	
23:00		1,509			1			1	

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Παρασκευή, 13 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ρ Α Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
01:00	1,248			1			1		
02:00	1,255			1			1		
03:00	1,213			1			1		
04:00	1,211			1			1		
05:00	1,261			1			1		
06:00	1,323			1			1		
07:00	1,512			1			1		
08:00	1,625	1		1			1		
09:00	1,648	1		1					
10:00	1,662	1		1					
11:00	1,694	1		1					
12:00	1,799	1		1					
13:00	1,769	1		1					
14:00	1,824	1		1					
15:00	1,683	1		1					
16:00	1,676	1		1					
17:00	1,904	1		1					
18:00	1,966		1	1					
19:00	1,921		1	1					
20:00	1,942		1	1					
21:00	1,866		1	1					
22:00	1,689		1	1					
23:00	1,478		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Σάββατο, 14 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
	Σάββατο, 14 Δεκεμβρίου 2024	00:00	1,359		1	1			
01:00		1,305		1	1				
02:00		1,276		1	1				
03:00		1,207		1	1				
04:00		1,208		1	1				
05:00		1,264		1	1				
06:00		1,346		1	1				
07:00		1,512		1	1				
08:00		1,623		1	1				
09:00		1,681		1	1				
10:00		1,559			1		1		
11:00		1,554			1		1		
12:00		1,563			1		1		
13:00		1,482			1		1		
14:00		1,444			1		1		
15:00		1,509			1		1		
16:00		1,611			1		1		
17:00		1,849			1		1		
18:00		1,964			1		1		
19:00		1,985				1	1		
20:00		1,926				1	1		
21:00		1,812				1	1		
22:00		1,679				1	1		
23:00		1,518				1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Κυριακή, 15 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
01:00	1,297				1	1			
02:00	1,264				1	1			
03:00	1,248				1	1			
04:00	1,253				1	1			
05:00	1,278				1	1			
06:00	1,350				1	1			
07:00	1,454				1	1			
08:00	1,541			1	1				
09:00	0,000				1				
10:00	1,609				1				
11:00	1,708				1		1		
12:00	1,669				1		1		
13:00	1,714			1	1		1		
14:00	1,705			1	1				
15:00	1,609			1	1				
16:00	1,608			1	1				
17:00	1,742			1	1				
18:00	1,811			1	1				
19:00	1,784			1	1				
20:00	1,868			1	1				
21:00	1,815			1	1				
22:00	1,647			1	1				
23:00	1,454			1	1				

Γενική διακοπή στις 09:00, λόγω βλάβης σε μονάδα του ΤΣΠ.

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Δευτέρα, 16 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
01:00	1,240			1	1				
02:00	1,226			1	1				
03:00	1,165			1	1				
04:00	1,187			1	1				
05:00	1,239			1	1				
06:00	1,338			1	1				
07:00	1,566			1	1				
08:00	1,715			1	1				
09:00	1,803			1	1				
10:00	1,813			1	1				
11:00	1,920			1	1				
12:00	2,049			1	1				
13:00	1,999			1	1				
14:00	1,818			1	1				
15:00	1,648			1	1				
16:00	1,694			1	1				
17:00	1,877			1	1				
18:00	2,025			1	1				
19:00	2,071			1	1				
20:00	2,024			1	1				
21:00	1,914			1	1				
22:00	1,773			1	1				
23:00	1,563			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τρίτη, 17 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
01:00	1,306			1	1				
02:00	1,266			1	1				
03:00	1,238			1	1				
04:00	1,258			1	1				
05:00	1,305			1	1				
06:00	1,426			1	1				
07:00	1,645			1	1				
08:00	1,683			1				1	
09:00	1,620			1				1	
10:00	1,513			1				1	
11:00	1,518			1				1	
12:00	1,450			1				1	
13:00	1,479			1				1	
14:00	1,512			1				1	
15:00	1,507			1				1	
16:00	1,594			1				1	
17:00	1,825			1				1	
18:00	1,959			1				1	
19:00	2,024			1		1			
20:00	1,994			1		1			
21:00	1,925			1		1			
22:00	1,760			1		1			
23:00	1,526			1		1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΚΥΡΟΥ		Απολογισμός Λειτουργίας	Τετάρτη, 18 Δεκεμβρίου 2024						
Αποδιδόμενη Ισχύς (MW)			1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G2	G3	G4	G5	G6	G7
01:00	1,307			1		1			
02:00	1,251			1		1			
03:00	1,246			1		1			
04:00	1,238			1		1			
05:00	1,277			1		1			
06:00	1,383			1		1			
07:00	1,593			1		1			
08:00	1,730			1		1			
09:00	1,743	1		1					
10:00	1,537	1		1					
11:00	1,473	1		1					
12:00	1,410	1		1					
13:00	1,473	1		1					
14:00	1,483	1		1					
15:00	1,490	1		1					
16:00	1,602	1		1					
17:00	1,933	1		1					
18:00	2,057			1			1		
19:00	2,032			1			1		
20:00	2,026			1			1		
21:00	1,908			1			1		
22:00	1,800			1			1		
23:00	1,576			1			1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης