

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 6 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
			Πέμπτη, 6 Φεβρουαρίου 2025	00:00	0,705		1		
01:00	0,685			1					
02:00	0,679			1					
03:00	0,681			1					
04:00	0,694			1					
05:00	0,702			1					
06:00	0,762			1					
07:00	0,777			1					
08:00	0,808			1					
09:00	0,826			1					
10:00	0,854			1					
11:00	0,856			1					
12:00	0,879			1					
13:00	0,918			1					
14:00	0,917			1					
15:00	0,940			1	1				
16:00	0,973			1	1				
17:00	1,019			1	1				
18:00	1,088			1	1				
19:00	1,129			1	1				
20:00	1,086			1	1				
21:00	1,010			1	1				
22:00	0,947			1					
23:00	0,896			1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 7 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Α Ρ Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,692		1						
02:00	0,685		1						
03:00	0,692		1						
04:00	0,709		1						
05:00	0,725		1						
06:00	0,766		1						
07:00	0,785		1						
08:00	0,808		1						
09:00	0,826		1						
10:00	0,852		1						
11:00	0,857		1						
12:00	0,878		1						
13:00	0,911		1						
14:00	0,932		1	1					
15:00	0,933		1	1					
16:00	0,981		1	1					
17:00	1,040		1	1					
18:00	1,130		1	1					
19:00	1,177		1	1					
20:00	1,153		1	1					
21:00	1,092		1	1					
22:00	1,031		1	1					
23:00	0,981		1						

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 8 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,687		1						
02:00	0,690		1						
03:00	0,705		1						
04:00	0,728		1						
05:00	0,747		1						
06:00	0,786		1						
07:00	0,811		1						
08:00	0,830		1						
09:00	0,821		1						
10:00	0,817		1						
11:00	0,812		1						
12:00	0,824		1						
13:00	0,847		1						
14:00	0,874		1						
15:00	0,918		1	1					
16:00	0,978		1	1					
17:00	1,065		1	1					
18:00	1,175		1	1					
19:00	1,223		1	1					
20:00	1,193		1	1					
21:00	1,123		1	1					
22:00	1,057		1	1					
23:00	0,997		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 9 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,708		1						
02:00	0,702		1						
03:00	0,711		1						
04:00	0,729		1						
05:00	0,743		1						
06:00	0,770		1						
07:00	0,794		1						
08:00	0,815		1						
09:00	0,813		1						
10:00	0,789		1						
11:00	0,779		1						
12:00	0,789		1						
13:00	0,804		1						
14:00	0,833		1						
15:00	0,872		1						
16:00	0,955		1	1					
17:00	1,033		1	1					
18:00	1,144		1	1					
19:00	1,193		1	1					
20:00	1,162		1	1					
21:00	1,087		1	1					
22:00	1,022		1	1					
23:00	0,955		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 10 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (ΜW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (ΜW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,767		1						
02:00	0,759		1						
03:00	0,762		1						
04:00	0,781		1						
05:00	0,794		1						
06:00	0,816		1						
07:00	0,846		1						
08:00	0,869		1						
09:00	0,873		1						
10:00	0,848		1						
11:00	0,841		1						
12:00	0,849		1						
13:00	0,865		1						
14:00	0,895		1						
15:00	0,937		1	1					
16:00	0,998		1	1					
17:00	1,077		1	1					
18:00	1,178		1	1					
19:00	1,222		1	1					
20:00	1,202		1	1					
21:00	1,143		1	1					
22:00	1,087		1	1					
23:00	1,027		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 11 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,760		1						
02:00	0,749		1						
03:00	0,761		1						
04:00	0,796		1						
05:00	0,823		1						
06:00	0,849		1						
07:00	0,887		1						
08:00	0,918		1						
09:00	0,940		1						
10:00	0,949		1						
11:00	0,960		1						
12:00	0,975		1	1					
13:00	0,986		1	1					
14:00	1,013		1	1					
15:00	1,030		1	1					
16:00	1,073		1	1					
17:00	1,126		1	1					
18:00	1,198		1	1					
19:00	1,234		1	1					
20:00	1,212		1	1					
21:00	1,157		1	1					
22:00	1,106		1	1					
23:00	1,048		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 12 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,732		1						
02:00	0,741		1						
03:00	0,765		1						
04:00	0,808		1						
05:00	0,844		1						
06:00	0,872		1						
07:00	0,912		1						
08:00	0,942		1						
09:00	0,965		1						
10:00	0,973		1						
11:00	0,989		1	1					
12:00	1,007		1	1					
13:00	0,987		1	1					
14:00	1,039		1	1					
15:00	1,011		1	1					
16:00	1,058		1	1					
17:00	1,120		1	1					
18:00	1,196		1	1					
19:00	1,225		1	1					
20:00	1,200		1	1					
21:00	1,144		1	1					
22:00	1,091		1	1					
23:00	1,030		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης