

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Πέμπτη, 20 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
			Πέμπτη, 20 Φεβρουαρίου 2025	00:00	0,662		1		
01:00	0,644			1					
02:00	0,646			1					
03:00	0,641			1					
04:00	0,660			1					
05:00	0,694			1					
06:00	0,761			1					
07:00	0,791			1					
08:00	0,812			1					
09:00	0,819			1					
10:00	0,815			1					
11:00	0,824			1					
12:00	0,876			1					
13:00	0,866			1					
14:00	0,851			1					
15:00	0,869			1					
16:00	0,926			1					
17:00	0,999			1	1				
18:00	1,083			1	1				
19:00	1,133			1	1				
20:00	1,141			1	1				
21:00	1,061			1	1				
22:00	0,996			1	1				
23:00	0,937			1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Παρασκευή, 21 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,638		1						
02:00	0,646		1						
03:00	0,655		1						
04:00	0,678		1						
05:00	0,707		1						
06:00	0,763		1						
07:00	0,800		1						
08:00	0,839		1						
09:00	0,851		1						
10:00	0,847		1						
11:00	0,845		1						
12:00	0,867		1						
13:00	0,895		1						
14:00	0,894		1						
15:00	0,961		1	1					
16:00	1,008		1	1					
17:00	1,092		1	1					
18:00	1,179		1	1					
19:00	1,225		1	1					
20:00	1,235		1	1					
21:00	1,174		1	1					
22:00	1,111		1	1					
23:00	1,040		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Σάββατο, 22 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Ρ Ρ Ε Ε Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
Σάββατο, 22 Φεβρουαρίου 2025	00:00	0,592		1					
	01:00	0,593		1					
	02:00	0,614		1					
	03:00	0,652		1					
	04:00	0,691		1					
	05:00	0,731		1					
	06:00	0,788		1					
	07:00	0,834		1					
	08:00	0,867		1					
	09:00	0,893		1					
	10:00	0,894		1					
	11:00	0,889		1					
	12:00	0,904		1					
	13:00	0,927		1					
	14:00	0,956		1	1				
	15:00	1,009		1	1				
	16:00	1,074		1	1				
	17:00	1,162		1	1				
	18:00	1,270		1	1				
	19:00	1,307		1	1				
	20:00	1,311		1	1				
	21:00	1,252		1	1				
	22:00	1,182		1	1				
	23:00	1,109		1	1				

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Κυριακή, 23 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,572		1						
02:00	0,599		1						
03:00	0,645		1						
04:00	0,687		1						
05:00	0,726		1						
06:00	0,777		1						
07:00	0,822		1						
08:00	0,862		1						
09:00	0,888		1						
10:00	0,910		1						
11:00	0,918		1						
12:00	0,947		1						
13:00	0,923		1						
14:00	0,915		1						
15:00	0,968		1	1					
16:00	1,044		1	1					
17:00	1,130		1	1					
18:00	1,264		1	1					
19:00	1,300		1	1					
20:00	1,306		1	1					
21:00	1,268		1	1					
22:00	1,189		1	1					
23:00	1,116		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Δευτέρα, 24 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,607		1						
02:00	0,631		1						
03:00	0,666		1						
04:00	0,707		1						
05:00	0,754		1						
06:00	0,802		1						
07:00	0,852		1						
08:00	0,886		1						
09:00	0,901		1						
10:00	0,905		1						
11:00	0,903		1						
12:00	0,921		1						
13:00	0,921		1						
14:00	0,939		1	1					
15:00	0,985		1	1					
16:00	1,052		1	1					
17:00	1,129		1	1					
18:00	1,252		1	1					
19:00	1,309		1	1					
20:00	1,315		1	1					
21:00	1,284		1	1					
22:00	1,217		1	1					
23:00	1,153		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Τρίτη, 25 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Ρ Ε Π Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,612		1						
02:00	0,656		1						
03:00	0,704		1						
04:00	0,761		1						
05:00	0,819		1						
06:00	0,870		1						
07:00	0,927		1						
08:00	0,959		1	1					
09:00	0,941		1	1					
10:00	0,932		1	1					
11:00	0,923		1	1					
12:00	0,941		1	1					
13:00	0,933		1	1					
14:00	0,951		1	1					
15:00	1,001		1	1					
16:00	1,063		1	1					
17:00	1,139		1	1					
18:00	1,263		1	1					
19:00	1,337		1	1					
20:00	1,349		1	1					
21:00	1,318		1	1					
22:00	1,240		1	1					
23:00	1,163		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Προτεινόμενος ΗΕΠ			Τετάρτη, 26 Φεβρουαρίου 2025				
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	
Α Ρ Χ Η	Χρονική στιγμή	Πρόβλεψη Μέσου Ωριαίου Φορτίου (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,771		1						
02:00	0,797		1						
03:00	0,833		1						
04:00	0,878		1						
05:00	0,928		1						
06:00	0,975		1	1					
07:00	1,029		1	1					
08:00	1,049		1	1					
09:00	0,999		1	1					
10:00	0,966		1	1					
11:00	0,933		1	1					
12:00	0,929		1						
13:00	0,913		1						
14:00	0,926		1						
15:00	0,976		1	1					
16:00	1,048		1	1					
17:00	1,139		1	1					
18:00	1,274		1	1					
19:00	1,359		1	1					
20:00	1,367		1	1					
21:00	1,325		1	1					
22:00	1,232		1	1					
23:00	1,136		1	1					

Μη διαθεσιμότητα μονάδας λόγω συντήρησης

Μη διαθεσιμότητα μονάδας λόγω βλάβης