

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τετάρτη, 26 Φεβρουαρίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,783					1			
02:00	0,745					1			
03:00	0,732					1			
04:00	0,743					1			
05:00	0,770					1			
06:00	0,810					1			
07:00	0,804					1			
08:00	0,755					1			
09:00	0,776					1			
10:00	0,840					1			
11:00	0,838					1			
12:00	0,953				1	1			
13:00	1,049				1	1			
14:00	0,998				1	1			
15:00	0,997				1	1			
16:00	1,022				1	1			
17:00	1,069				1	1			
18:00	1,191				1	1			
19:00	1,216				1	1			
20:00	1,239				1	1			
21:00	1,182				1	1			
22:00	1,089				1	1			
23:00	0,948				1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Πέμπτη, 27 Φεβρουαρίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,818					1			
02:00	0,794					1			
03:00	0,765					1			
04:00	0,756					1			
05:00	0,762					1			
06:00	0,842					1			
07:00	0,856					1			
08:00	0,856					1	1		
09:00	0,854					1	1		
10:00	0,887					1	1		
11:00	0,921					1	1		
12:00	0,912					1	1		
13:00	0,920					1	1		
14:00	0,933					1	1		
15:00	0,965					1	1		
16:00	0,990					1	1		
17:00	1,047					1	1		
18:00	1,090					1	1		
19:00	1,150					1	1		
20:00	1,100					1	1		
21:00	1,043					1	1		
22:00	0,955					1	1		
23:00	0,881					1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Παρασκευή, 28 Φεβρουαρίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,756					1			
02:00	0,748					1			
03:00	0,711					1			
04:00	0,716					1			
05:00	0,734					1			
06:00	0,793					1			
07:00	0,798					1			
08:00	0,745					1			
09:00	0,738					1			
10:00	0,701					1			
11:00	0,660					1			
12:00	0,673					1			
13:00	0,692					1			
14:00	0,817					1			
15:00	0,938				1	1			
16:00	1,000				1	1			
17:00	1,012				1	1			
18:00	1,059				1	1			
19:00	1,103				1	1			
20:00	1,077				1	1			
21:00	1,039				1	1			
22:00	0,965				1	1			
23:00	0,848				1	1			

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Σάββατο, 1 Μαρτίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,730					1			
02:00	0,710					1			
03:00	0,689					1			
04:00	0,709					1			
05:00	0,715					1			
06:00	0,760					1			
07:00	0,775					1			
08:00	0,816					1			
09:00	0,815					1			
10:00	0,838					1	1		
11:00	0,784					1	1		
12:00	0,791					1	1		
13:00	0,792					1	1		
14:00	0,910					1	1		
15:00	0,927					1	1		
16:00	1,006					1	1		
17:00	1,080					1	1		
18:00	1,193					1	1		
19:00	1,251					1	1		
20:00	1,189					1	1		
21:00	1,110					1	1		
22:00	0,996					1	1		
23:00	0,909					1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Κυριακή, 2 Μαρτίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,816					1			
02:00	0,785					1			
03:00	0,768					1			
04:00	0,761					1			
05:00	0,776					1			
06:00	0,826					1			
07:00	0,817					1			
08:00	0,897					1			
09:00	0,955					1	1		
10:00	0,869					1	1		
11:00	0,738					1	1		
12:00	0,689					1	1		
13:00	0,668					1			
14:00	0,686					1			
15:00	0,750					1			
16:00	0,832					1			
17:00	0,910					1	1		
18:00	1,014					1	1		
19:00	1,118					1	1		
20:00	1,124					1	1		
21:00	1,055					1	1		
22:00	0,973					1	1		
23:00	0,884					1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Δευτέρα, 3 Μαρτίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,760					1			
02:00	0,749					1			
03:00	0,740					1			
04:00	0,732					1			
05:00	0,759					1			
06:00	0,831					1			
07:00	0,824					1	1		
08:00	0,885					1	1		
09:00	0,998					1	1		
10:00	1,064					1	1		
11:00	1,021					1	1		
12:00	0,987					1	1		
13:00	0,972					1	1		
14:00	0,881					1	1		
15:00	0,862					1	1		
16:00	0,878					1	1		
17:00	0,963					1	1		
18:00	1,040					1	1		
19:00	1,102					1	1		
20:00	1,068					1	1		
21:00	1,040					1	1		
22:00	0,938					1	1		
23:00	0,891					1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης

ΗΣ ΣΕΡΙΦΟΥ		Απολογισμός Λειτουργίας		Τρίτη, 4 Μαρτίου 2025					
Αποδιδόμενη Ισχύς (MW)		0,400	1,100	1,100	1,100	1,100	1,100	1,100	1,100
Η Ε Ρ Ρ α	Χρονική στιγμή	Πραγματικό Μέσο Ωριαίο Φορτίο (MW)	G1	G3	G4	G5	G6	G7	G10
01:00	0,741						1		
02:00	0,713						1		
03:00	0,699						1		
04:00	0,714						1		
05:00	0,727						1		
06:00	0,786						1		
07:00	0,816						1		
08:00	0,905						1		
09:00	0,928						1		
10:00	1,029						1		
11:00	0,960					1	1		
12:00	0,985					1	1		
13:00	0,997					1	1		
14:00	1,017					1	1		
15:00	1,074					1	1		
16:00	1,111					1	1		
17:00	1,164					1	1		
18:00	1,210					1	1		
19:00	1,224					1	1		
20:00	1,170					1	1		
21:00	1,097					1	1		
22:00	0,999					1	1		
23:00	0,917					1	1		

Μη διαθεσιμότητα μονάδας λόγω συντήρησης  
 Μη διαθεσιμότητα μονάδας λόγω βλάβης